



**FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION**

Southwest District Office
13051 North Telecom Parkway
Temple Terrace, Florida 33637-0926

RICK SCOTT
GOVERNOR

CARLOS LOPEZ-CANTERA
LT. GOVERNOR

HERSCHEL T. VINYARD JR.
SECRETARY

NOTIFICATION OF ACCEPTANCE OF USE OF A GENERAL PERMIT

PERMITTEE:

Sia Mollanazar, P.E.
Deputy Director, Engineering
Manatee County
1022 26th Ave. East
Bradenton, FL 34208
Sia.mollanazar@mymanatee.org

PERMIT NUMBER: CS41-0182063-155-DWC/CG

ISSUE DATE: July 10, 2014

EXPIRATION DATE: July 9, 2019

COUNTY: Manatee

PROJECT NAME: Force Main 1 MA Replacement

WASTEWATER TREATMENT FACILITY:

Manatee County SW Regional WWTF

FACILITY ID: FLA012619

Dear Mr. Mollanazar:

This letter acknowledges receipt of your Notification/Application for Constructing a Domestic Wastewater Collection/Transmission System for the subject project. Our Office received the Notice on July 7, 2014.

This is to advise you that the Department does not object to your use of this general permit for the following: construction of 8-inch diameter force main to replace an existing 6-inch diameter force main.

Please note the attached requirements apply to your use of this general permit for constructing the proposed domestic wastewater collection/transmission system.

You are further advised that the construction activity must conform to the description contained in your Notification/Application for Constructing a Domestic Wastewater Collection/Transmission System and that any deviation may subject the permittee to enforcement action and possible penalties.

If you have any questions, please contact Dr. Ramandeep Kaur at (813) 470-5771 or via email at Ramandeep.Kaur@dep.state.fl.us.

Sincerely,

FOR 

Kelley M. Boatwright
Program Administrator
Permitting & Waste Cleanup Program
Southwest District










cc: Jim Stockwell, P.E., Manatee County Public Works, jim.stockwell@mymanatee.org
Andy Fischer, Manatee County Public Works Dept., andy.fischer@mymanatee.org

PROJECT NAME: Force Main 1 MA replacement
PERMIT NUMBER: CS41-0182063-155-DWC/CG

REQUIREMENTS FOR USE OF THE GENERAL PERMIT FOR DOMESTIC WASTEWATER COLLECTION/TRANSMISSION SYSTEMS:

1. This general permit is subject to the general permit conditions of Rule 62-4.540, F.A.C., as applicable. This rule is available at the Department's Internet site at:
<http://www.dep.state.fl.us/water/rulesprog.htm#ww> [62-4.540]
2. This general permit does not relieve the permittee of the responsibility for obtaining a dredge and fill permit where it is required. [62-604.600(6)(b)1]
3. This general permit cannot be revised, except to transfer the permit. [62-604.600(6)(b)2]
4. This general permit will expire five years from the date of issuance. If the project has been started and not completed by that time, a new permit must be obtained before the expiration date in order to continue work on the project. [62-4.030]
5. Upon completion of construction of the collection/transmission system project, and before placing the facilities into operation for any purpose other than testing for leaks or testing equipment operation, the permittee shall submit to the Department's Southwest District Office Form 62-604.300(8)(b), Request for Approval to Place a Domestic Wastewater Collection/Transmission System into Operation. This form is available at the Department's Internet site at:
<http://www.dep.state.fl.us/water/wastewater/forms.htm> [62-604.700(2)]
6. The new or modified collection/transmission facilities shall not be placed into service until the Department clears the project for use. [62-604.700(3)]
7. Abnormal events shall be reported to the Department's Southwest District Office in accordance with Rule 62-604.550, F.A.C. For unauthorized spills of wastewater in excess of 1000 gallons per incident, or where information indicates that public health or the environment may be endangered, oral reports shall be provided to the STATE WATCH OFFICE TOLL FREE NUMBER (800)320-0519 as soon as practical, but no later than 24 hours from the time the permittee or other designee becomes aware of the circumstances. Unauthorized releases or spills less than 1000 gallons per incident are to be reported orally to the Department's Southwest District Office within 24 hours from the time the permittee, or other designee becomes aware of the circumstances. [62-604.550]

LOCATION OF PUBLIC WATER SYSTEM MAINS IN ACCORDANCE WITH F.A.C. RULE 62-555.314

Other Pipe	Horizontal Separation	Crossings (1)	Joint Spacing @ Crossings (Full Joint Centered)
Storm Sewer, Stormwater Force Main, Reclaimed Water (2)			<p>Alternate 3 ft. minimum</p> 
Vacuum Sanitary Sewer			<p>Alternate 3 ft. minimum</p> 
Gravity or Pressure Sanitary Sewer, Sanitary Sewer Force Main, Reclaimed Water (4)			<p>Alternate 6 ft. minimum</p> 
On-Site Sewage Treatment & Disposal System	10 ft. minimum	---	---

- (1) Water main should cross above other pipe. When water main must be below other pipe, the minimum separation is 12 inches.
- (2) Reclaimed water regulated under Part III of Chapter 62-610, F.A.C.
- (3) 3 ft. for gravity sanitary sewer where the bottom of the water main is laid at least 6 inches above the top of the gravity sanitary sewer.
- (4) Reclaimed water not regulated under Part III of Chapter 62-610, F.A.C.

Disclaimer -- This document is provided for your convenience only. Please refer to F.A.C. Rule 62-555.314 for additional construction requirements.