



Financial Management Department  
Procurement Division  
1112 Manatee Ave West, Suite 803  
Bradenton, FL 34205  
Phone: (941) 749-3074  
www.mymanatee.org

July 10, 2017

TO: All Interested Quoters

SUBJECT: Request for Quotation (RFQ) 17-1546BLS  
Pool Heater for GT Bray Dive Well

ADDENDUM 1

Quoters are hereby notified that this Addendum shall be acknowledged on page Quotation Form-1 of the Quote Form and made a part of the above named quoting and contract documents. Quotes submitted without acknowledgment of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the quotation and contract documents. These items shall have the same force and effect as the original quoting and contract documents, and cost involved shall be included in the quote prices. Quotations to be submitted on the specified quote date, shall conform to the additions and revisions listed herein.

**CLARIFICATION**

1. Pool size = 13 x 17ft
2. Bathing load = 15 persons (2-3 times per week – maximum)
3. Slide feature is not operated from November through March
4. Cover: thermal cover used at night – November through March
5. Core drill block and pipe; flow in/out (x2); 4" diameter
6. Disinfection System: calcium hypochlorite
7. The Lochinvar OKN801 Outdoor Knight Heating Boiler unit (or equal) meets all specifications listed in the RFQ. Signature on quotation form shall confirm ALL specifications shall be met or exceeded.

Quotations will be received at Manatee County Procurement, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until July 14, 2017 at 3:00pm.

Sincerely,

for Chris Daley, CPPO, CPPB  
Buyer Manager

/bls