



1112 Manatee Avenue West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

---

Addendum No.: 1  
Solicitation No.: 24-R084907RB  
Solicitation Title: Highland Shores Boat Ramp Repair  
Addendum Date: July 10, 2024  
Procurement Contact: Ryan Blackmer, Procurement Agent III

**ITQ No. 24-R084907RB is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of ITQ No. 24-R084907RB.**

**The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this ITQ was July 8, 2024.**

### QUESTIONS AND RESPONSES:

**Q1. Please confirm retainage amount for the project. On page 5 of the ITQ it states “Payment will be made in accordance with Florida State Statutes and with a payment schedule approved by the County and the Successful Bidder.” The statute states “an amount not exceeding 5 percent of the payment as retainage.”**

R1. Refer to the Florida State Statute.

**Q2. Are there liquidated damages for this project? If so, what is the amount?**

R2. \$150.00 per day.

**Q3. Is there a warranty period? If so, what is the duration?**

R3. 1 year.

**Q4. On sheet 6 cross section C-C, it calls for 7’3” of 10” DR32.5 HDPE pipe cut in half. This sized HDPE would not fit around the 10” pile as the average ID of the HDPE is 8.062”. Please clarify which size HDPE size should be quoted.**

R4. The average ID for a 10” DR32.5 HDPE pipe is 10.05”. Bid in accordance with plans and specifications.

**Q5. On sheet 6 cross section F-F, it calls for 7'3" of 8" DR32.5 HDPE pipe cut in half. This sized HDPE would not fit around the 8" pile as the average ID of the HDPE is 6.193". Please clarify which size HDPE size should be quoted.**

R5. The average ID for an 8" DR32.5 pipe is 8.06". Bid in accordance with plans and specifications.

**Q6. Can fend-all dock fenders be quoted in lieu of the HDPE sleeves? If so, please specify which model and color would be required.**

R6. Bid in accordance with the plans and specifications.

**NOTE:**

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the ITQ.

**INSTRUCTIONS:**

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

**END OF ADDENDUM**

AUTHORIZED FOR RELEASE