



Financial Management Department
Purchasing Division
1112 Manatee Ave W Suite 803
Bradenton, FL 34205
Phone: (941) 749-3074
www.mymanatee.org

Email

September 7, 2017

TO: All Interested Bidders

SUBJECT: Invitation for Bid (IFB) #17-0101DC
Village of Parrish Force Main and Master Pump Station
ADDENDUM 11

Bidders are hereby notified that this Addendum shall be acknowledged and made a part of the above named bidding and contract documents.

The following items are issued to add to, modify, and/or clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

1. To compensate for the impending storm, the Bid Opening is extended to **3:30 on September 20, 2017**, same location.
2. Deadline for clarifications has passed.

The following questions have been presented by potential bidders:

3. Question: Please clarify, Regarding the note in addendum #9 Pump station gate valves... Needle and slot position indicator is this a visual indicator or an electronic that is sent to a panel?

Response: Electronic proximity switches, include wiring / conduit back to PLC for controls.

Bids will be received at Manatee County Procurement, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until **September 20, 2017 at 3:30 P.M.**

Sincerely,

Chris Daley, CPPB, CPPO
Buyer Manager

/dcr