



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 3
Solicitation No.: 24-TA004989DJ
Project No.: 6109670
Solicitation Title: LMWTP Sedimentation Basin C Sludge Collection Upgrade
Addendum Date: December 22, 2023
Procurement Contact: Dave Janney, Procurement Agent III

IFBC 24-TA004989DJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 24-TA004989DJ.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was December 15, 2023.

QUESTIONS AND RESPONSES:

Q1. I was just looking for clarification between the Manatee Co APL and project specs. The existing valves being replaced and mentioned in the plans, specs, and bid form don't all match up with the County APL which is referenced to be followed in each valve section. Should we replace the existing valves exactly in kind or provide new valves per the latest County APL?

Example: Existing Dezurik AC Swing Checks to be replaced, but they are not on the County APL

R1. We need to meet the specification for the valves at the plant. Please reference a like-for-like replacement and the specification for the valve replacement.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE