



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 4
Solicitation No.: 23-R081797LP
Solicitation Title: Blackstone Park Chainlink Fence Backstops
Addendum Date: July 3, 2023
Procurement Contact: Leslie Peer

IFBC 23-R081797LP is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 23-R081797LP.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was June 23, 2023.

QUESTIONS AND RESPONSES:

- Q1. Can the post sizes be switched to 8-5/8"OD in either sch40 or sch80(as per the 30' high backstop installed at GT Bray) so that the posts can be properly powder coated? XXstrong can not be powder coated or vinyl coated and can only be painted by hand in the field which does not meet paint specifications.**
- R1 The post sizes are based on the spacing of the posts. For the spacing currently shown, the thickness indicated on our drawings are required per current code and wind load ratings. The only way to reduce the thickness of the pipe is to space the posts closer together; doing so requires re-engineering, soil borings, and reduction in site-lines for spectators. This is not feasible currently. A proposal of an alternative method of coating the post will be acceptable.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE