



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 2
Solicitation No.: 24-TA005632LP
Project No.: 6115560
Solicitation Title: Rye Road at Fire Station 3 Emergency Signal
Addendum Date: October 30, 2024
Procurement Contact: Leslie Peer

IFBC 24-TA005632LP is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 24-TA005632LP.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was October 28, 2024.

QUESTIONS AND RESPONSES:

Q1. In regards to the generator housing, the pay item listed calls for "install only," but there is a note found on plan sheet T-5 of the Signal plans that says that the contractor is to *furnish* and install the generator housing, and to reach out to Manatee County for the desired housing dimensions. Could the County please provide clarification on whether the County is looking for the contractor to furnish as well as install the housing and what the dimensions of that cabinet would be?

R1. The clarifying note for pay item 639-4-6 on sheet T-5 is correct. The County is needing the contractor to both furnish and install the generator cabinet housing and does not include the generator itself. The typical generator cabinet housing is from Transportation Control Systems with an outside dimension of 36"X26".

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE