



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 2
Solicitation No.: 25-R086424DJ
Solicitation Title: Generator and Pump Preventative Maintenance
Addendum Date: March 24, 2025
Procurement Contact: Dave Janney

IFB 25-R086424DJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFB 25-R086424DJ.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFB was March 21, 2025.

CHANGE TO:

EXHIBIT 1 SCOPE OF SERVICES, 1.02 SCOPE OF WORK, PARAGRAPH A2.

2. Provide **3 quarterly** inspections:

Everything in the annual service minus:

- Oil change with corresponding filter change.
- Fuel filter
- Transfer switch operation
- Oil and coolant samples

QUESTIONS AND RESPONSES:

Q1. Are any of the units high voltage (4160 and above)?

R1. There are approximately 4 units at 4160 volts.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFB.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE