



1112 Manatee Ave. West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 2

Solicitation No.: 18-TA002841JP

Solicitation Title: Force Main Replacement Package A: FM 28A, Port Manatee and Orlando Avenue

Addendum Date: October 29, 2018

Procurement Contact: Joe Pretorius, johannes.pretorius@mymanatee.org

IFBC NO. 18-TA002841JP IS AMENDED AS SET FORTH HEREIN. RESPONSES TO QUESTIONS POSED BY PROSPECTIVE BIDDERS ARE PROVIDED BELOW. THIS ADDENDUM IS HEREBY INCORPORATED IN AND MADE A PART OF IFBC NO. 18-TA002841JP.

Add:

SECTION 01150 MEASUREMENT AND PAYMENT

BID ALTERNATIVE – CLOSE TOLERANCE HDD

Payment for all work included under this Bid Alternative shall be made at the Contract unit price bid per the schedule of prices for furnishing and Certa-Lok PVC DR 18 pipe by close tolerance directional drill and associated connection pipe sections as shown on the Contract Drawings. As part of the testing methods for the HDPE pipe installation, the Contractor shall televise or pull a mandrill through the installed HDPE pipe to verify sound installation.

Measurement and Payment shall be made for the actual length of the listed diameter pipe close tolerance directional drilled and installed, and will represent full compensation for all labor, materials, excavation, including rock, dewatering, bedding, backfill, compaction, testing, pipe restraints, mud trailer, and equipment required to complete these Bid Items. No additional compensation shall be made for excavation below the bottom of the pipe, for rock removal or bedding and backfill material, or for repair of any trench settlement. No additional compensation shall be made for extensive dewatering or any water treatment services or equipment that may be required for contaminated groundwater.

<u>BID ITEM</u>	<u>DESCRIPTION</u>	<u>UNITS</u>
<u>11A</u>	<u>6" Close Tolerance HDD</u>	<u>LF</u>
<u>43A</u>	<u>4" Close Tolerance HDD</u>	<u>LF</u>

Replace:

APPENDIX J, BID FORM

Appendix J, Bid Form, is replaced with the attached Appendix J, Bid Form revised per this Addendum No. 2. An electronic copy of Appendix J is available at www.mymanatee.org and www.demandstar.com. Revisions have been made as follows:

1. Changed: Item No. 19 \pm 2" ARV;
2. Changed: Item No. 49 \pm 2" ARV;
3. Changed: Item No. 78 \pm 2" ARV.

QUESTIONS AND RESPONSES:

Q1. Specs say that all T-bolts, nuts and rods are to be 316SS, typically only the nuts and rods for the pipe to pipe restraints (bell joint) required 316SS, but T-bolts are used on MJ restraints (megalugs) which normally don't require 316SS, please clarify if 316SS T-bolts/nuts for the MJ restraints (megalugs) are required.

R1. All hardware shall be 316SS. However, as an alternative the County will accept High Strength, Low Alloy Steel, conforming to AWWA C111/A21.11-17 or ASTM A242 standards, with blue fluoropolymer coating (Xylan 1424 or FluoroKote #1).

Q2. Plan profiles call for the air release valves to be 2" but the bid form calls for them to be 1", please clarify.

R2. All ARV's is 2". Please see the revised Appendix J Bid Form.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in IFBC No. 18-TA002841JP.

End of Addendum

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE: 