



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 2
Solicitation No.: 24-R084063BB
Solicitation Title: Corrosion & Odor Control Services
Addendum Date: March 13, 2024
Procurement Contact: Brooke Baker, CPPB, NIGP-CPP, Procurement Agent III

Request for Proposals (RFP) No. 24-R084063BB is amended as set forth herein. Responses to questions posed by prospective proposers are provided below. This Addendum is hereby incorporated in and made a part of RFP No. 24-R084063BB.

QUESTIONS AND RESPONSES:

Q1. Is Manatee County open to receiving bid submissions for proposals involving alternate chemicals?

R1. No.

Q2. Page 3 (45 of PDF)1.03 OPTION 1: CALCIUM NITRATE – GENERAL REQUIREMENTS, Paragraph J. Can the County confirm that the Continuous gas monitoring shall be only at the immediate downstream location of any Calcium Nitrate dosing location?

R2. Would be downstream of a feed site but would be designated by Manatee County and may not be specifically the immediate downstream location.

Q3. Page 3 (45 of PDF)1.03 OPTION 1: CALCIUM NITRATE – GENERAL REQUIREMENTS, Paragraph J. Shall the continuous H₂S data be remotely viewable by the Contractor and the County on a daily basis?

R3. Yes.

Q4. Page 3 (45 of PDF)1.03 OPTION 1: CALCIUM NITRATE – GENERAL REQUIREMENTS, Paragraph K. Currently the service frequency is a minimum of once per month. Can the County confirm that it wishes to increase the frequency of service/sampling to a minimum of once per every 15 days as this will significantly increase the manhours?

- R4. The expiring contract is also once every 15 days, so nothing is changing with this requirement.
- Q5. Page 6 (48 of PDF)1.05 OPTION 2: MAGNESIUM HYDROXIDE – GENERAL REQUIREMENTS, Paragraph E. Shall all Electrical installation by the contractor conform to County electrical codes? If so shall any existing installations that do not meet current codes be upgraded?**
- R5. Yes, all electrical installations, current and future, shall meet all NEC and Manatee County electrical codes.
- Q6. Page 6 (48 of PDF)1.05 OPTION 2: MAGNESIUM HYDROXIDE – GENERAL REQUIREMENTS, Paragraph F. Shall the tanks provided be double wall like the calcium nitrate tanks to prevent leaks?**
- R6. No.
- Q7. Page 6 (48 of PDF)1.05 OPTION 2: MAGNESIUM HYDROXIDE – GENERAL REQUIREMENTS, Paragraph I. Shall the H2S monitoring be continuous?**
- R7. No.
- Q8. Page 6 (48 of PDF)1.05 OPTION 2: MAGNESIUM HYDROXIDE – GENERAL REQUIREMENTS, Paragraph I. Shall the continuous H2S data be remotely viewable by the Contractor and the County on a daily basis?**
- R8. Does not apply.
- Q9. Page 8 (59 of PDF)EXHIBIT 2, PROPOSAL RESPONSE, 2.02 PROPOSAL FORMAT, K. TAB 9 – FEE PROPOSAL, FEE FORM – OPTION 1: CALCIUM NITRATE, Item 4. Do vapor phase installations require continuous Inlet/Outlet Monitoring for H2S?**
- R9. Yes, the County would like continuous Inlet/Outlet Monitoring for H2S at vapor phase installations.
- Q10. We are considering putting in a bid for the MgOH2 under the current request 24-R084063BB. We would like to request current pricing for the Magnesium Hydroxide being supplied and any additional cost associated with servicing the location(s). We are requesting pricing as we need to see if this is economically viable for us, as the number of lift stations and service hours appear to be a large part of the contract.**
- R10. Premier Magnesia, LLC
- \$3.309 per gallon
 - Tank rental fee of \$450.00/unit/month
 - Tank maintenance fee of \$50.00/unit/month

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the RFP.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE