



1112 Manatee Ave. West
 Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 2
 Solicitation No.: 19-TA003154AJ
 Project No.: 6028387
 Solicitation Title: FORCEMAIN 30A REPLACEMENT
 Addendum Date: November 14, 2019
 Procurement Contact: Abigail Jenkins

IFBC 19-TA003154AJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of IFBC 19-TA003154AJ

Change to:

ADVERTISEMENT, DATE, TIME AND PLACE DUE:

The Due Date and Time for submission of Bids in response to this IFBC is **November 20, 2019 at 3:00 P.M. ET**. Bids must be delivered to the following location: Manatee County Administration Building, 1112 Manatee Ave. W., Suite 803, Bradenton, FL 34205 prior to the Due Date and Time.

Change to:

INFORMATION FOR BIDDERS, FIRST PARAGRAPH OF SECTION A.01 BID DUE DATE:

The Due Date and Time for submission of Bids in response to this Invitation for Bid (IFBC) is **November 20, 2019 at 3:00 P.M. ET**. Bids must be delivered to the following location: Manatee County Administration Building, 1112 Manatee Ave. W., Suite 803, Bradenton, FL 34205 and time stamped by a Procurement representative prior to the Due Date and Time.

Change to:

INFORMATION FOR BIDDERS, SECTION A.51 SOLICITATION SCHEDULE

The following schedule has been established for this Solicitation process. Refer to the County’s website (www.mymanatee.org > Online Services > *Bids & Proposals*) for meeting locations and updated information pertaining to any revisions to this schedule.

Scheduled Item	Scheduled Date
Final Addendum Posted	<u>November 14, 2019</u>
Bid Response Due date and Time	<u>November 20, 2019, 3:00 PM, ET</u>
Due Diligence Review Completed	November 2019
Projected Award	December 2019

Change to:

ADDENDUM 1, RESPONSE TO QUESTON Q4

Q4. Existing manhole 14471 – This manhole has a fiberglass liner (in good condition). Does the county want to remove & replace?

R4. The existing liner shall be removed, the concrete walls shall be rehab as needed, and an approved new spray liner shall be applied.

Change to:

ADDENDUM 1, RESPONSE TO QUESTON Q5

Q5. Existing manhole 12329 – This manhole appears to have a Raven 405 liner (in good condition). Does the county want to remove & replace or touch up?

R5. The existing liner shall be removed, the concrete walls shall be rehab as needed, and an approved new spray liner shall be applied.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFBC.

End of Addendum

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE