



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 2
Solicitation No.: 22-TA004011DJ
Solicitation Title: 26th Avenue East from 27th Street E to Sugar Creek Sidewalk and
26th Street East FM Replacement
Project No.: 6098660
Addendum Date: February 25, 2022
Procurement Contact: Dave Janney
Senior Procurement Agent

IFBC 22-TA004011DJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 22-TA004011DJ.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was February 15, 2022.

REPLACE:

BID ATTACHMENT 4 PLANS, PLAN SHEETS 8, 9, 10, and 13.

Replace Bid Attachment 4 Plans, Sheets 8, 9, 10, 13 with Revised Plan Sheets 8, 9, 10, 13 issued with this Addendum 2 and available for download as a separate attachment.

REPLACE:

SECTION B, BID FORMS, APPENDIX K, BID PRICING FORM

Replace Appendix K Bid Pricing Form, with the Revised Appendix K Bid Pricing Form hereby incorporated into the IFBC.

QUESTIONS AND RESPONSES:

Q1. Pay item # 23 30'' enwalls has a quantity of 2 each. I can only identify 1 on the plans. Please review.

R1. There is one 30” endwall at ST 114+14.8 LT, two 36” endwall at ST 121+65. See Addendum No. 2, Appendix K Bid Pricing Form (Revision 2). Changes highlighted in yellow.

Q2. On the same pay item # 23 there seems to be not enough information on how this is being constructed. There is no height given. Please clarify.

R2. The endwalls shall be constructed per FDOT Index 430-030.

Q3. Can you provide the bid form in excel please.

R3. See attached Addendum No. 2, Appendix K Bid Pricing Form (Revision 2).

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the RFQ.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE