



1112 Manatee Ave. West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.:	3
Solicitation No.:	19-TA003135BB
Solicitation Title:	Gravity Sewer Replacement – Port Manatee
Addendum Date:	October 24, 2019
Procurement Contact:	Brooke Baker

IFBC No. 19-TA003135BB is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of 19-TA003135BB.

QUESTIONS AND RESPONSES:

- Q1. Was the sewer line inspected? If so, were the locations of the service laterals identified in the inspection report?**
- R1. A Closed Circuit Television Inspection (CCTV) of the sewer line was performed. The approximate locations of the service laterals were identified in the CCTV report and are illustrated in Attachment 3, Plan Set Drawings.
- Q2. Are the sewage flows expected to increase?**
- R2. It is anticipated that no additional connections will be made to the gravity sewer system during construction, thus no increase to typical flows.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFBC.

End of Addendum

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE