



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 1
Solicitation No.: 23-TA004867LP
Project No.: 6110070
Solicitation Title: Summer Place Condos Waterline Replacement
Addendum Date: September 28, 2023
Procurement Contact: Leslie Peer

IFBC No. 23-TA004867LP is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC No. 23-TA004867LP.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was September 18, 2023.

REPLACE:

SECTION B, BID FORMS, APPENDIX L, BID PRICING FORM

Replace Appendix L Bid Pricing Form, with Appendix L Bid Pricing Form Revised issued with this Addendum 1.

SECTION C, BID ATTACHMENTS, BID ATTACHEMENT 2, – TECHNICAL SPECIFICATIONS

Replace Summer Place Condos WM Replacement Technical Specifications in its entirety with Bid Attachment 2 Technical Specifications Revised issued with this Addendum 1 as a separate attachment.

SECTION C, BID ATTACHEMNTS, BID ATTACHEMNT 3, – PLAN SET/ DRAWINGS

Replace Summer Place Condos WM Replacement Plan Set / Drawings in its entirety with Bid Attachment 3 Plan Set / Drawings Revised issued with this Addendum 1 as a separate attachment.

QUESTIONS AND RESPONSES:

Q1. Is a construction cost estimate or budget associated with the Summer Place Condos Waterline Replacement Project?

R1. The estimated opinion of cost is \$2,438,873.00.

Q2. On sheet 8 of 19 the plan calls out to install 68 LF of 6” DIP across 15th Street (US 301). Does the County have a permit for this work?

R2. This portion of 15th Street East is not a state road. Manatee County has designated 15th Street East / 301 Boulevard East as a Principle Arterial, according to the Manatee County Comprehensive Plan Traffic Element. The road is owned and maintained by Manatee County and is not on the State Highway System. The road is also designated as County Road (CR) 683.

Q3. I do not see a MOT plan provided in the set of plans for this work on 15th Street (US 301). Will one be provided?

R3. No, MOT plan will be provided by contractor prior to commencement of construction. See Section C, Bid Attachments, Bid Attachment 2, - Technical Specifications note 24 and note 65 through note 66 on Sheet 2 Notes.

Q4. Does the proposed 6” water line work on sheet 8 of 19 crossing 15th Street (US 301) require it to be performed at night?

R4. No, Contractor can do work over night with prior approval from the County.

Q5. Plan sheet 17 of 19 provided with detail UG 12 does not meet the FDOT specifications for the asphalt replacement crossing 15th Street (US 301). The FDOT specification for asphalt is SP MIX AND FC MIX. Please clarify.

R5. On County Roads, SI and SIII asphaltic concrete will suffice, while on State Road an.SP equivalent is required. This portion of 15th Street East is not a state road. Manatee County has designated 15th Street East / 301 Boulevard East as a Principle Arterial, according to the Manatee County Comprehensive Plan Traffic Element. The road is owned and maintained by Manatee County and is not on the State Highway System. The road is also designated as County Road (CR) 683.

Q6. On plan sheet 8 can the proposed 6” water line crossing 15th Street (US 301) by open cut be changed to HDD?

R6. No, to limit the depth of the pipe we want to maintain its current method of installation.

Q7. Can you provide the bid form in excel?

R7. Excel version of Appendix L Bid Pricing Form Revised (fillable) is available for download as a separate attachment.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE

APPENDIX L, BID PRICING FORM REVISED

IFBC 23-TA004867LP

Summer Place Condo Waterline Replacement

PROJECT NUMBER: 6110070

WATER LINES 6-INCH & UNDER							
ITEM NO.	DESCRIPTION	UNITS	QTY.	BID A UNIT PRICE 330 CALENDAR DAYS (\$)	BID A EXTENDED PRICE 330 CALENDAR DAYS	BID B UNIT PRICE 330 CALENDAR DAYS (\$)	BID B EXTENDED PRICE 330 CALENDAR DAYS
Bidders must provide prices for each line item for this to be considered responsive							
1	Pavement Repair & Road Restoration						
1.01	Road Pavement Base	SY	1,432				
1.02	Road Pavement Asphalt	SY	1,700				
1.03	Mill & Overlay	SY	7,027				
2	Sidewalk Replacement, conc. (4" min. thick.)	SY	23				
3	Sodding	SY	800				
4	Grout Fill Abandoned Pipe	CY	32				
5	2" Blow-off Assembly	EA	3				
6	Permitting Fees- Building Dept.- BPA Installation	EA	5				
7	Backflow Prevention Assemblies						
7.01	DC 3/4"	EA	10				
7.02	RPZ 3/4"	EA	39				
8	Remove Ex. Utilities						
8.01	2" Gate Valve	EA	1				
8.02	6" Gate Valve	EA	19				
8.03	Fire Hydrant Assembly	EA	2				
9	Pipe						
9.01	2" COPPER, (SDR-9)	LF	23				
9.02	4" PVC, (C-900)	LF	80				
9.03	6" PVC, (C-900)	LF	596				
9.04	4" DIP, (Class 350)	LF	31				
9.05	6" DIP, (Class 350)	LF	2,984				
9.06	2" PE, (SDR-9)	LF	578				
9.07	4" HDPE, (DR-11)	LF	117				
	10 4" Steel Casing Pipe (Class 350)	LF	50				
40-11	Water Services						
40.01 11.01	1" PE Single Service (Short)	EA	13				
40.02 11.02	1" PE Single Service (Long), w/ 2" casing	EA	27				
40.03 11.03	1" PE Double Service (Short)	EA	3				
40.04 11.04	1" PE Double Service (Long), w/ 2" casing	EA	13				
40.05 11.05	Additional 1" Service Pipe over 10' (Short) & 30' (Long)	LF	302				
41-12	Ductile Iron Fittings						
41.01 12.01	4" Plug x 2" Compression Fitting, DI	EA	3				
41.02 12.02	4" 45 Degree Bend, MJ	EA	2				
41.03 12.03	6"x4" Reducer, MJ	EA	2				
41.04 12.04	6" 22.5 Degree Bend, MJ	EA	2				
41.05 12.05	6" 45 Degree Bend, MJ	EA	30				
41.06 12.06	6" 90 Degree Bend, MJ	EA	1				
41.07 12.07	6"x4" Cross MJ	EA	1				
41.08 12.08	6" Tee, MJ	EA	8				
41.09 12.09	6" Tee, MJ (Cut-in)	EA	1				
42-13	Pipe Joint Restraints						
42.01 13.01	4"	EA	6				
42.02 13.02	6"	EA	174				
43-14	HDPE Pipe Adapter, MJ						
43.01 14.01	2"	EA	6				
43.02 14.02	4"	EA	2				
44-15	Valves						
44.01 15.01	2" Gate Valve	EA	2				
44.02 15.02	4" Gate Valve	EA	1				
44.03 15.03	6" Gate Valve	EA	11				
45-16	Fire Hydrant Assembly	EA	3				
46-17	Thermoplastic Striping						
46.01 17.01	Stop Bar, White, 24"	LF	12				
46.02 17.02	White, 6"	LF	40				
46.03 17.03	Double Yellow, 6"	LF	80				
47-18	Erosion Control	LS	1				
48-19	Silt Fence	LF	9				
49-20	Inlet Protection	EA	16				
20-21	Traffic Control	LS	1				
21-22	Misc. Concrete, 3,000 psi	CY	5				
	Sub Total Construction Cost						
22-23	Mobilization (10% of SubTotal)	10%	1				
23-24	Record Drawings	LS	1				
24-25	Contingency (Used with prior County approval only)	10%	1				
	Total Construction Cost						

Added

*To be considered responsive, it is the sole responsibility of the bidder to correctly calculate and manually enter all sub-total, contingency, and total bid price fields.

Bidder: _____

Signature: _____