



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 1
Solicitation No.: 23-TA004683ED
Project No.: 6110280
Solicitation Title: Artisan Lakes Master Lift Station Rehabilitation
Addendum Date: May 16, 2023
Procurement Contact: Emily Diaz, Procurement Agent III

IFBC 23-TA004683ED is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 23-TA004683ED.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was May 15, 2023.

REPLACE:

APPENDIX K – BID PRICING FORM

APPENDIX K – BID PRICING FORM

Replace Appendix K – Bid Pricing Form with the Appendix K – Bid Pricing Form Revised (revised per Addendum 1).

QUESTIONS AND RESPONSES:

Q1. Could you please provide the budget or engineer's estimate for the referenced project?

R1. The Engineer's opinion of probable construction cost is \$1,147,774.00.

Q2. Does the County have a way to isolate the force main for the connection point or is a line stop needed?

R2. Refer to Bid Attachment 3 – Drawings, page 9 of 18 for plug valve location.

Q3. Are fusion couplings allowed on the HDPE piping?

R3. Fusion couplings are not allowed on HDPE piping.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE