



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 1
Solicitation No.: 22-R079371JH
Solicitation Title: C Basin High Service Pump and Motor Replacement
Addendum Date: July 19, 2022
Procurement Contact: Jeb Hayter

IFB 22-R079371JH is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFB 22-R079371JH.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFB is July 8, 2022.

QUESTIONS AND RESPONSES:

Q1. Who will be providing the crane?

R1. The County will let the contractor use its overhead crane.

Q2. Can you provide the stainless-steel hardware list?

R2. The contractor shall survey the job and make sure to provide all hardware they need to complete the job.

Q3. Will the County provide new mechanical seal?

R3. County will not provide. The mechanical seal will be provided and installed by contractor. The seal must be Chesterton mechanical split seal.

Q4. If awarded the opportunity, will we be able to take the motor and pump to our shop to epoxy coat and paint the assembly / machine prior to installation?

R4. Yes, it would be best for the contractor to receive the equipment shipment direct to their shop to do work before installation.

Q5. Will the County be providing the blue paint that matches the existing piping? if not, what is the color code?

R5. The County will provide blue paint color code.

Q6. Do we need to take / deliver the old pump to a particular location once removed?

R6. No, The County will have a trailer in place to receive the old pump and motor and remove them from the area.

Q7. Will the old pump and motor be reconditioned / rebuilt?

R7. No

Q8. Please clarify the request for providing certification as a pump and motor shop?

R8. Bidder's license and certification as a pump and motor shop is required to meet the Minimum Qualification Requirements as outlined in IFBC No. 22-R079371JH.

Q9. Please clarify if any additional manufacturers are able to quote this high service pump?

R9. The County wants to keep the same Floway Pump manufacturer for replacement.

Q10. The contract states 14 calendar days to complete. The lead time for the pump assembly and motor is anticipated to be 15-25 weeks. Will time be awarded to the contractor once submittals are provided with lead times?

R10. The specified 14 calendar days for completion are from the time the contractor starts construction and begins to remove the old pump and motor.

Q11. The existing pump is Floway brand. Will the County allow for other brands to be considered? If so, please provide approved vertical turbine brands that the County will accept.

R11. Refer to R9.

Q12. Can you confirm the pump must be NSF 61 certified as mandated by FDEP?

R12. NFS61 is required.

Q13. Does the motor need to be inverter duty rated suitable for VFD usage?

R13. Yes, inverter duty motor wire / winding required.

Q14. Is standard 12-month warranty acceptable?

R14. Please build in 36 months (3 year) warranty.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFB.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE