



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 2
Solicitation No.: 22-TA004105SAM
Project No.: 6107960
Solicitation Title: Lockwood Ridge Rebase & Resurface
Addendum Date: May 26, 2022
Procurement Contact: Sherri Meier

IFBC No. 22-TA004105SAM is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC No. 22-TA004105SAM.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC is May 16, 2022.

CHANGE TO:

ADVERTISEMENT, SECOND PARAGRAPH, DATE, TIME AND PLACE DUE:

The Due Date and Time for submission of Bids in response to this Invitation for Bid Construction (IFBC) is ~~June 2, 2022~~ **June 6, 2022 at 2:00 PM ET**. Bids must be delivered to the following location: Manatee County Administration Building, 1112 Manatee Ave. W., Suite 803, Bradenton, FL 34205 prior to the Due Date and Time.

CHANGE TO:

SECTION A, INFORMATION FOR BIDDERS, ITEM A.01 BID DUE DATE:

The Due Date and Time for submission of Bids in response to this Invitation for Bid Construction (IFBC) is ~~June 6, 2022~~ **June 6, 2022 at 2:00 PM ET**. Bids must be delivered to the following location: Manatee County Administration Building, 1112 Manatee Ave. W., Suite 803, Bradenton, FL 34205 and time stamped by a Procurement representative prior to the Due Date and Time.

CHANGE TO:

SECTION A, INFORMATION FOR BIDDERS, ITEM A.51 SOLICITATION SCHEDULE

| Scheduled Item | Scheduled Date |
|-------------------------------------|--|
| Question and Clarification Deadline | May 16, 2022 |
| Final Addendum Posted | May 24, 2022 |
| Bid Response Due Date and Time | June 2, 2022, <u>June 6, 2022, 2:00 PM, ET</u> |
| Projected Award | July 2022 |

QUESTIONS AND RESPONSES:

- Q1. In Addendum 1 you have now provided a spec for green paint which spells out method of measurement and payment will be by the square foot (which is the FDOT standard for these items) yet your bid sheet has unit of measure linear foot. This is conflicting. Can you please revise the bid sheet to a sf unit of measure which is standard?**
- R1. See Revised Appendix K, Bid Form hereby incorporated into the IFBC and available for download as a separate attachment.
- Q2. You have stated that Valve and Manhole adjustments will be paid under pay items U1 to U5 under a separate document. There is no separate document, you only have items U1 to U3 on the bid form, and there is no mention of manholes at all.**
- R2. There is no Manhole adjustment shown in the plan. Only Valve adjustment is needed, under item U1 to U3. The U4 and U5 were the old pay items for utility mobilization and contingency and not applicable anymore. Please disregard U4 &5.
- Q3. There are several conflicting statements in Addendum 1. Can you review and revise?**
- a. Road closures will not be allowed between the hours of 6AM to 7PM**
 - b. Road closures are ONLY permitted from 7AM to 4PM**
 - c. Night work may be considered given Manatee County review and approval**

The interpretation of the above is that contractor must work during lane closures from 7AM to 4PM (which we would assume is actually the times of the HIGHEST traffic volumes), yet if we need to close a road and detour, it must be done at night time, but now we can only work at night if approved by the County.

R2. Lane Closures are permitted between 7AM and 4 PM unless night closures are approved by the County.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE