



MANATEE COUNTY

April 27, 2009

TO: All Interested Bidders

SUBJECT: Invitation for Bid #09-1151-OV
Cortez Road & Elwood II Booster Pump Stations
Portable Emergency Generators, Bradenton, FL

ADDENDUM #3

Bidders are hereby notified that this Addendum shall be acknowledged on page 00300-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

Bidders:

Answers to the questions have been provided by Mr. Craig Osmanski, P.E., URS Corporation.

Clarifications:

Sheet E-7 is associated with Elwood II, sheet E-5 is associated with Cortez; however, at the Cortez installation the single line diagram requires four (4) 3-inch (one spare) between the utility transformer and the MCC (through the MCB and MTS). The plan view on drawing E-4 shows the conduit routing but does not reference the spare 3-inch conduit. Follow the conduit count as shown on drawings E-5 "Single Line Diagram" and provide the spare 3-inch conduit grouped with the three (3) active 3-inch conduits.

The 1600A MCB at Elwood II is required to be 100% rated, the 900A MCB at Cortez is not required to be 100% rated.

On The Drawings:

Sheet E-4, Reference Note 7; Delete Reference Note 7 and replace with new Reference Note 7 as follows:

"Note 7: Provide four (4) 3-inch RGS conduits routed exposed between "MTS" and the existing MCC."

Financial Management Department – Purchasing Division
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
Phone: 941-749-3014 – Fax: 941-749-3034

LARRY BUSTLE * DR. GWENDOLYN Y. BROWN * JOHN R. CHAPPIE * RON GETMAN * DONNA G. HAYES * CAROL WHITMORE * JOE
MCCLASH

District 1

District 2

District 3

District 4

District 5

District 6

District 7

April 27, 2009
Invitation for Bid #09-1151-OV
Cortez Road & Elwood II Booster Pump Stations
Portable Emergency Generators, Bradenton, FL

END OF ADDENDUM #3

Bids will be received at the **Manatee County Purchasing Division, 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205** until **2:00 P.M. on May 5, 2009.**

Sincerely,



R. C. "Rob" Cuthbert, CPM, CPPO
Purchasing Division Manager

Financial Management Department – Purchasing Division
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
Phone: 941-749-3014 – Fax: 941-749-3034

**LARRY BUSTLE * DR. GWENDOLYN Y. BROWN * JOHN R. CHAPPIE * RON GETMAN * DONNA G. HAYES * CAROL WHITMORE * JOE
MCCLASH**
District 1 District 2 District 3 District 4 District 5 District 6 District 7