

MANATEE COUNTY FLORIDA

FACSIMILE

February 19, 2009

TO: All Interested Bidders

SUBJECT: Invitation for Bid #09-0748DC
63rd Avenue Bridge over Pearce Canal

ADDENDUM #1

Bidders are hereby notified that this Addendum shall be acknowledged on the Bid Form pages and made a part of the above named bidding and contract documents.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

1. Information Conference sign-in sheet is attached.
2. The ARVs are to be above ground. Reference Manatee county Public Works Utility Standard Sheet UW-19 dated 3/18/1997, revised 11/99 – copy can be purchased from Manatee County Engineering, 941-792-8811 x5039.
3. Profile Sheet – The invert for the bottom of the 16" water main is at elevation -2.5.
4. Manatee County shall provide the Pile Driving Analysis.
5. SDR 11 is to elastic and is not acceptable for this project application.


Financial Management Department - Purchasing Division
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
PHONE: 941.749.3074 * FAX: 941.749.3034
www.mymanatee.org

6. In reference to road detour: The contractor will secure a Right-of-Way Use Permit from Manatee County. Submission of the maintenance of traffic and road closure schedules will be required.
7. Reference Invitation for Bid, Special Provisions (page 100-4, item 5) – Professional Engineer is required for submittals in relation to bridge deck design.
8. The existing piles will be completely removed by the contractor.
9. Plan page B-13 notes that 10 cubic yards of concrete is included in the superstructure pay item for the approach slab sidewalk overlay. The thickness of the superstructure sidewalk is 10” prior to the 4” overlay and is included in the pay item for the Class IV Concrete (Superstructure).
10. Plan page B-6 – Change reference “...sheet B-15...” to read “...sheet B-10...”. There is no page B-15.

If you have submitted a bid prior to receiving this addendum you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

Bids will be received at Manatee County Purchasing, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until **February 24, 2009 at 3:00 P.M.**

Sincerely,


R.C. "Rob" Cuthbert, C.P.M.
Purchasing Division Manager

/dcr

INFORMATION CONFERENCE: INVITATION FOR BID

IFB #09-0748DC 63rd Ave Bridge over Pearce Canal

DATE: February 3, 2009

TIME: 10:00 A.M.

TELEPHONE/ FAX/ EMAIL	NAME (PLEASE PRINT)	COMPANY NAME
P-941.749.3074 F-941.749.3034 deborah.carey-reed@mymanatee.org	DEBORAH CAREY-REED	PURCHASING
813-888-8366 813-884-5850 MIKE WELKE@WADETRIM.COM	Michael Reincke	Wade Trim
352 629 0224 (P) 352 629 0314 (F) DBECKEDORF@MICOINDEV.NET	Don Beckedorf	Micon
941-224-0723 keelabella@coastal-fla.com	KEITH COLABELLA	Coastal Const. Prod.
941-755-4312 941-758-7184 lovin-construction-venezia.net	Tonia Lovin	LOVIN Construction Co.
941-757-8080 941-757-8085 roy.serpess@engineering.com	Roy Smith	Russell Engineering, Com
941-708-7450 BY 7332	Walter Soma, III	Manatee County
941-708-7344	MIKE O'REILLY	MANATEE CO.
813-673-0516 813-673-1602	DAN EGAN	Cone & Gardner
941-756-1871	RICK HOFFMAN	Woodsruff & Sons
749-3045	Donna M Stevens	MCG
P-407.562.4620	DAVID SHUBERG	BRADFORD L GORRIS, LLC
F-407.562.4501 ASHUBERG@BRADFORDGORRIS.COM		
749-3046	LONNIE SIETMAN	MCG
941-379-6603	PAUL KUXHAUSEN	Kuxhausen Const. Inc
FAX 377-9875	KEN KUXHAUSEN	
PH. 239-267-8778	ZELJKO SARONIC	ZEP Construction, Inc.
239-267-7907	ZEP Constr., Inc.	

Project
MANATEE COUNTY PROJECT MANAGEMENT TEAM IN ATTENDANCE:

WALT SOWA, Project Manager 708-7450 x7332
Engineer - WADE TRIM 813-882-8366