



MANATEE COUNTY

April 6, 2011

All Interested Bidders:

**SUBJECT: IFB #11-0576-OV Manatee County Utilities Maintenance
and Administration Building
Bradenton, FL (Project No. 60697)**

ADDENDUM #3

Bidders are hereby notified that this Addendum shall be acknowledged on page 00300-1 of the Revised Bid Form which was provided with Addendum No. 1 and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

Bidders Note: Additional questions shall not be accepted at this time as the stated deadline of **March 18, 2011** has lapsed. This deadline has been established to maintain fair treatment of all potential bidders, while maintaining the expedited nature of the Economic Stimulus that the contracting of this work may achieve.

Bidders Note:

Bid Opening Date has been revised:

From: April 7, 2011 at 4:00 PM

To: April 12, 2011 at 2:00 PM

Financial Management Department – Purchasing Division
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
Phone: 941-749-3055 – Fax: 941-743-3034
www.mymanatee.org

LARRY BUSTLE * MICHAEL GALLEN * JOHN R. CHAPPIE * ROBIN DISABATINO * DONNA G. HAYES * CAROL WHITMORE * JOE McCLASH
District 1 District 2 District 3 District 4 District 5 District 6 District 7

April 6, 2011
IFB #11-0576-OV Manatee County Utilities Maintenance
and Administration Building
Bradenton, FL (Project No. 60697)
Page 2 / Addendum No. 3

Attachment:

- Clarifications No. 1 from SchenkelShultz dated April 6, 2011 regarding specification requirement 13 34 19-9 H.

Roof Panel Joints shall be allowed. Minimum Panel Length shall be 45' – 0".

If you have submitted a bid prior to receiving this addendum, you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

END OF ADDENDUM #3

Bids will be received at the **Manatee County Purchasing Division, 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205** until **200 P.M. on April 12, 2011.**

Sincerely,



R. C. "Rob" Cuthbert, C.P.M, CPPO
Purchasing Division Manager

Ov/ Attachments (1 Total Pages)

PROJECT NAME: UTILITIES MAINTENANCE & ADMINISTRATION BUILDING

Manatee County

ADDENDUM NUMBER 3

Date of Issue: April 06, 2011

Bidders are hereby notified that this Addendum shall be acknowledged on the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete. The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

Clarifications:

Clarification 1: Disregard the specification requirement 13 34 19-9 H stating that no panel joints will be allowed for roof panels. Roof panel joints shall be allowed. Minimum panel length shall be 45'-0".

Above concludes Addendum No.3,



Dražen Ahmedić, AIA
Associate
SSA project #0920826