



MANATEE COUNTY FLORIDA

November 6, 2013

TO: All Interested Bidders
SUBJECT: Invitation for Bids #13-1745CD
Fort Hamer Road Water Main Crossing

ADDENDUM #3

Bidders are hereby notified that this Addendum shall be acknowledged on page 00300-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgment of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

1. **CHANGE** the Due Date and Time to **Wednesday, November 13, 2013 at 3:00 PM.**

The following question was presented after the issuance of Addendum #2:


Question 1: Reference Addendum Two, Question 31, Response 31, what type of air test are we to conduct, a low pressure type? If low pressure type, how much air test pressure are we to maintain and for how long? Please clarify.

Response 1: The pre-installation air test shall be a low pressure test, less than 4 psi. The test shall be conducted for a maximum of 2 hours. The purpose of this test is to test for joint weld integrity only. The acceptance test shall be a hydrostatic test in accordance with Article 1.02 of Section 02617 on page 111 of the Technical Specification Contract Documents, and must be conducted after the HDPE pipe has been installed.

END OF ADDENDUM #3

Bids will be received at Manatee County Purchasing, 1112 Manatee Avenue West, Bradenton, Florida 34205 until **Wednesday, November 13, 2013 at 3:00 PM.**

Sincerely,


Melissa M. Wendel, CPPO
Purchasing Official

Financial Management Department –Purchasing Division
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
PHONE: 941.749.3014 * FAX: 941.749.3034

www.mvmanatee.org