



1112 Manatee Ave. West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 1
Solicitation No.: 18-TA002591OV
Project No.: 6074770
Solicitation Title: Suburban System Water Line Replacement, Phase 3, Bradenton, FL
Addendum Date: November 29, 2017
Procurement Contact: Olga Valcich, 941-749-3055 (olga.valcich@mymanatee.org)

IFB 18-TA002591OV IS AMENDED AS SET FORTH HEREIN. RESPONSES TO QUESTIONS POSED BY PROSPECTIVE BIDDERS ARE PROVIDED BELOW. THIS ADDENDUM IS HEREBY INCORPORATED IN AND MADE A PART OF IFB 18-TA002591OV. THE DUE DATE AND TIME FOR SUBMISSION OF BIDS IN RESPONSE TO THIS INVITATION FOR BID (IFB) IS DECEMBER 15, 2017 3:00 P.M. ET.

Add:

SPECIFIC PURPOSE SURVEY OF SUBURBAN WATERLINE RIGHT OF WAY CORRIDOR

The attached Specific Purpose Survey of Suburban Waterline Right of Way Corridor, dated September 10, 2013 is hereby incorporated into Exhibit 4, Plan Set.

Replace:

EXHIBIT 1, TECHNICAL SPECIFICATIONS, TABLE OF CONTENTS

Replace Exhibit 1, Technical Specifications Table of Contents dated July 1, 2017 with the attached revised Exhibit 1, Table of Contents dated November 27, 2017 which adds Section 02064, Modifications to Existing Structures, Piping and Equipment.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added. All other terms and conditions remain as stated in the <solicitation type>.

QUESTIONS AND RESPONSES:

Q1. Reference specifications Section 01150 MEASUREMENT AND PAYMENT, page 44/206, BID ITEM No. 36 and 37: IN-PLACE PIPE ABANDONMENT, second paragraph, we will not need a licensed asbestos abatement contractor for filling the existing asbestos cement pipe with concrete grout, please remove this paragraph.

R1. Removal and Abandonment of Asbestos Cement Pipe and Appurtenances is addressed by Technical Specification 02064, MODIFICATIONS TO EXISTING STRUCTURES, PIPING AND EQUIPMENT, paragraph 3.03 (page 97/206). The work of 'In-place Pipe Abandonment' involves more than just filling the existing pipe with concrete (e.g. disconnecting the asbestos cement pipe from existing pipe and making exposed ends of asbestos pipe ready to receive concrete fill and expel displaced air). Some means and methods selected by the contractor may need to be performed by a licensed asbestos abatement contractor registered in the State of Florida to meet the standards listed in paragraph 3.03 C. It is the intent of Manatee County that the bid price submitted include all the work described including furnishing the services of a licensed asbestos abatement contractor as may be required by governing regulatory agencies and for obtaining required permits.

Q2. Reference specifications Section 01720, RECORD DRAWINGS, PART 2, PRODUCTS, page 87/206, par. 2.02, MONUMENTATION, please provide the survey this project was designed by in order for our professional land surveyor to assess costs associated with monumentation.

R2. 'Survey' has been incorporated into the IFB per this Addendum 1.

End of Addendum

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE: 