



1112 Manatee Avenue West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

### Solicitation Addendum

---

Addendum No.: 4  
Solicitation No.: 21-TA003519DJ  
Project No.: 6081101  
Solicitation Title: Portosueno Park South Seawall Replacement  
Addendum Date: December 10, 2020  
Procurement Contact: Dave Janney  
Senior Procurement Agent

**IFBC 21-TA003519DJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of IFBC 21-TA003519DJ.**

### QUESTIONS AND RESPONSES:

**Q1. Sheet 2 in the Plans call for reinforcing steel: ASTM Grade 60 Carbon Steel per FDOT Specifications section 931 and Sheet 23 calls for reinforcing steel to be hot dipped galvanized per ASTM A-153 with 2 ounces of zinc per sq ft. Please verify material for reinforcing steel.**

R1. Use uncoated reinforcing steel as referenced on Sheet 2, Note 25, of the plans.

### NOTE:

Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFBC.

### INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

### END OF ADDENDUM

AUTHORIZED FOR RELEASE