



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 2
Solicitation No.: IFBC 21-TA003698JH
Project No.: 6092460
Solicitation Title: 26th Street West at 30th Avenue West Intersection
Improvements
Addendum Date: May 28, 2021
Procurement Contact: Jeb Hayter

IFBC 21-TA003698JH is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 21-TA003698JH.

QUESTIONS AND RESPONSES:

Q1. Reference specifications Section 01590, COUNTY'S FIELD OFFICE, is this really necessary? There is no room for a field office, and it is a waste of Taxpayer's money, please delete this from the specifications.

R1. The complete set of County Infrastructure Engineering Standard Specifications were included with only edits to Sections 01010 Summary of Work and 01150 Measurement and Payment. The County's Field Office is not required for this project.

Q2. Reference specifications Bid Form, IV, POTABLE WATER (UTILITIES), Pay Item No. 89, 4"-6" Gate Valves (Restrained Joint), the bid quantity shows 4-each, plans show 3-each 4-inch valves, the 6-inch valve, that is to be installed with the Hydrant Relocation in Pay Item No. 92, is to be paid as part of the hydrant relocation pay item according to the Measurement and Payment Section for Pay Item No. 92. There is no call out for a 6-inch valve on the plans. Please review and correct quantity and pay item description.

R2. The quantity for Pay Item No. 89 (MC-2) is correct. The project has three (3) 4" Gate Valves and one new (1) 6" Gate Valve for the hydrant. The pay item description is not changed as it covers 4"-6" sizes.

Q3. Reference plan sheet U-5, Note 1, this note contradicts what the Measurement and Payment description for Pay Item No. 92 regarding Hydrant Relocation describes, please clarify.

R3. Hydrant relocation shall include a new 6” Gate Valve (Pay Item No. 89 / MC-2) and a new 6” Tee (Pay Item No. 91 / MC-4) per Sheet U-5, Note 1. The Measurement and Payment description for Pay Item No. 92 / MC-5 covers all other incidental items for the hydrant relocation.

Q4. Reference specifications Section 01580, PROJECT IDENTIFICATION AND SIGNS, page 64 of 490, par. 1.02, PROJECT IDENTIFICATION SIGN (COUNTY), this paragraph requires two (2) each signs, now reference specifications SPECIAL PROVISIONS, page 6, par. PROJECT IDENTIFICATION SIGNS, first paragraph, first sentence, this requires the Contractor provide three (3) each project signs, how many signs are we to provide?

R4. The Special Provisions control the Project Identification Signs. Three (3) project signs shall be provided.

Q5. Reference plan sheet U-5, the note to POST RESTRAIN the existing 4” AC WM, please provide a detail to accomplish restraining asbestos cement pipe.

R5. Post restraintment of the 4” AC WM is achieved with the thrust blocks at the adjacent 45 degree fittings on either end. The thrust block detail is provided on UG-7 on Sheet U-7.

Q6. The specs are calling for a field office for the engineer. Will this be required, or the spec deleted?

R6. The complete set of County Infrastructure Engineering Standard Specifications were included with only edits to Sections 01010 Summary of Work and 01150 Measurement and Payment. The County’s Field Office is not required for this project.

Q7. There are many specification s included that reference a building with the various components, IE: Painting, Thermo protection, Hoists & Cranes, Plumbing, Etc. Are these to be disregarded as there is no building in this scope of work?

R7. The complete set of County Infrastructure Engineering Standard Specifications were included with only edits to Sections 01010 Summary of Work and 01150 Measurement and Payment to define the utility work for this project.

Q8. There are specs for an Emergency Generator Set and another Portable Generator Set. What exactly are we to provide?

R8. The complete set of County Infrastructure Engineering Standard Specifications were included with only edits to Sections 01010 Summary of Work and 01150 Measurement and Payment to define the utility work for this project.

The only generator on the bid form is for FDOT Pay Item Reference 639-4-6, controlled by FDOT Specifications. There is also Pay Item Note #5 that provides additional direction regarding this pay item.

Q9. The specs reference 2 sites for generators to be installed. The bid proposal is for 1. Please clarify what we are to furnish and where it is to be delivered?

R9. The complete set of County Infrastructure Engineering Standard Specifications were included with only edits to Sections 01010 Summary of Work and 01150 Measurement and Payment to define the utility work for this project.

The only generator on the bid form is for FDOT Pay Item Reference 639-4-6, controlled by FDOT Specifications. There is also Pay Item Note #5 that provides additional direction regarding this pay item.

Q10. I am submitting a substitution request for your consideration on the following product under section 0820 Fiberglass Reinforced Plastic Doors and Frames. Special Lite series FRP doors and frames model number AF-200?

R10. The complete set of County Infrastructure Engineering Standard Specifications were included with only edits to Sections 01010 Summary of Work and 01150 Measurement and Payment. There are no doors required for this project.

NOTE:

Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE