

MEMORANDUM



To: All Interested Quoters **OV**
Date: **14** **September 6, 2017**
Subject: RFQ17-1414OV, Kingfish Boat Ramp Seawall Repair
752 Manatee Avenue, Holmes Beach, FL 34217
Addendum No. 2 **2** **OV**

Quoters are hereby notified to acknowledge this Addendum No. 2 on page 1 of the Quote Form and made a part of the above-named quoting and contract documents.

The following items are issued to add to, modify, and clarify the quote and contract documents. These items shall have the same force and effect as the original quoting document, and cost involved shall be included in the quote prices. Quotes to be submitted on the specified quote date, shall conform to the additions and revisions listed herein.

The deadline of **August 29, 2017 at 5:00 pm** to submit all inquiries concerning interpretation, pertaining to this quote has expired.

Original reply date: September 13, 2017 at 3:00 PM.

Revised reply date: September 20, 2017 at 3:00 PM

Quoters Note: Reference Section A – Information to Quoters, Page 1: Article Titled Purpose:
REMOVE: "It is the intent of the County of Manatee.... **(REMOVE Mechanical Contractor).**"

REPLACE: "It is the intent of the County of Manatee to procure the expertise of a **General Contractor or a Marine Contractor to provide**..... (Reference Section C.01 Quote Summary, Minimum Qualifications to Quoters).

The following questions have been presented by potential quoters:

- Q1: When would you expect this project to start?
- R1: **Anticipated start date is 30 days after award of project.**
- Q2: I would like to propose our Prime Flex 920 polyurethane as an approved material.
- R2: **Prime Flex 920 as an alternative for this project is not approved as it will not be known if the vertical slab joint will be fully sealed by the grout that is pumped behind the vertical joint. All quoters are directed to quote on the product specified within the specifications.**

Financial Management Department
Procurement Division
1111 Manatee Avenue West, Suite 1902
Palmdale, Florida 34653

IFB17-1414OV
Kingfish Boat Ramp Seawall Repair
Page 2 of 2
Addendum ¹⁴ ~~17~~ September ~~6~~, 2017

- Q3: Are alternative repair suggestions accepted?
- R3: **All quoters are directed to quote on the Work as stated in the specification.**
- Q4: Are longer than normal work hours allowed?
- R4: **All Work shall be performed during normal work hours: 8:00 am to 5:00 pm, Monday through Friday, with no weekends.**
- Q5: Are individual site visits permitted?
- R5: **Yes, individual site visits are permitted. This is an open public facility. Quoters shall acknowledge visit of the project site on Quote Form, page 1. The intent of the project site visit is to ensure that the quoters have familiarized themselves with the full scope of work required for this solicitation.**

This Request for Quotation solicitation is not a sealed quote process. **Therefore, replies may be provided via email to olga.valcich@mymanatee.org. Replies shall be submitted on September 20, 2017 at 3:00 pm.**

Sincerely yours,



Olga Valcich, CPPB, Contract Specialist
Manatee County Procurement Division

Ov