



1112 Manatee Ave. West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

---

Addendum No.:	4
Solicitation No.:	20-R073858AJ
Project No.:	6073402
Solicitation Title:	Manatee County Jail – Stockade Roof Replacement
Addendum Date:	May 22, 2020
Procurement Contact:	Abigail Jenkins

**IFBC No. 20-R073858AJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of IFBC No. 20-R073858AJ.**

**ADD:**

**ATTACHMENT 6, BUILDING ELEVATIONS AS-BUILT DRAWINGS**

The attached Attachment 6, Building Elevations as Built Drawings, is hereby incorporated into this Addendum 4.

**ADD:**

**ATTACHMENT 7, ROOF PENETRATION DIMENSIONS**

The attached Attachment 7, Roof Penetration Dimensions, is hereby incorporated into this Addendum 4.

**CHANGE TO:**

**BID ATTACHMENT 2, TECHNICAL SPECIFICATION, 4.0 MEASUREMENT AND PAYMENT, 4.8 BID ITEM DESCRIPTIONS, B. BID ITEM NO. 2 DEMOLITION AND REMOVAL OF EXISTING ROOF, NO. 1, PAGE 61 AND 62.**

Payment for all work included in this Bid Item shall include all work necessary to coordinate and administer all parts indicated in the specifications, including but not limited to the preparation of the substrate surface, removal and disposal of existing roof membrane/system(s) and flashings down to the existing insulation, removal of the existing lightning protection system, preparation of roofing insulation, and wood nailers for roofing

attachment as required. Remove and dispose of the 3 sets of wooden stairs located on the South, East and West sides of the upper roof portion.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFBC.

## **END OF ADDENDUM**

### **INSTRUCTIONS:**

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE

**ATTACHMENT 7, ROOF PENETRATION DIMENSIONS****IFBC 20-R073858AJ MANATEE COUNTY JAIL - STOCKADE ROOF REPLACEMENT**

Annex B Roof Penetration Dimensions				
Quantity	Type	L	W	H
38	A/C curb	5'	3'	12"
28	Exhaust Fan	20"	20"	12"
7	Air Exchange curb	4'	4'	10"
6	Sky Light	18"	18"	10"

