



MANATEE COUNTY
FLORIDA

January 29, 2009

TO: All Interested Bidders

SUBJECT: Invitation for Bid # 09-0505-DS
Lakewood Ranch Master Lift Station

ADDENDUM # 1

Bidders are hereby notified that this Addendum shall be acknowledged on pages 00300-2 & 00300-3 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

Based upon instructions from the Project Manager, Mr. Sal Bordonaro, Manatee County Government, Public Works Department.

Q1. Bid form requires two delineators—for 220 days and 270 days.

A1. Answer: Two separate bid forms have been created denoting days. Please see attached.

END OF ADDENDUM # 1

Bids will be received at the Manatee County Purchasing Division, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until 2:00 P.M. on February 27, 2009.

Sincerely,

R. C. "Rob" Cuthbert, CPM, CPPO
Purchasing Division Manager

ds

Finance Management Department
Mailing Address: Purchasing Division: 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
PHONE: 941-749-3045 * FAX: 941-749-3034
www.mymanatee.org

BID FORM
SECTION 00300
 (Submit in Triplicate)
IFB# 09-0505-DS
220 Calendar Days

PROJECT NAME: Lakewood Ranch Master Lift Station
PROJECT NUMBER: 404-606781
SECTION/TWNSHP/RANGE: 20-35-19
PROJECT DESCRIPTION: Rehab wetwell and piping for lift station
PROJECT SITE DIMENSIONS: All work is within the lift station parcel

LIFT STATION

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	4"x 8" DI Eccentric Reducer, FLG	EA	5		
2	By-Pass Pumping	LS	1		
3	Spraywall Liner (Repair) – Wet Well	SF	100		
4	Drain Down & Clean Wet Well	LS	1		
5	Remove Base Ells, Anchors, Piping, Valves, Bracing, Supports	LS	1		
6	8" SCH 10 S. S. (.316L) Piping W/Welded SS Flanges	LF	80		
7	4" Pump Base Ells & Base Plates (Grinding/Leveling and Grout As Req'd)	EA	5		
8	EBBA Series 2100 Mega Flange Restrained FLG Adapter or Approved Equal	EA	15		
9	8"- 90 Degree Bend, SCH 10 SS (316L) w/Welded SS	EA	5		
10	S.S. Adjustable Pipe Support	EA	5		
11	8" Swing Check Valve	EA	5		
13	Install ¼"x 2 S.S. (304) Pipe Bracing System	EA	10		
14	DI Fittings	LB	100		
15	Retain/Reinstall Exist. S. S. Pump Guide Rail System	LF	5		
16	Install New Linkseal at WW Wall for SCH 10 SS Piping	EA	5		
17	Asphalt Driveway Repair: Remove & Replace Inc. Subgrade	SY	18		
18	Mobilization (Max 10% of Total Bid)	LS	1		
19	Miscellaneous Work & Clean Up (% of Sub Total)	LS	1		
20	Discretionary				\$ 15,800.00
TOTAL BID PRICE					

Acknowledged Addendum No. _____ Dated _____
 BIDDER _____

BID FORM
SECTION 00300
 (Submit in Triplicate)
IFB# 09-0505-DS
270 Calendar Days

PROJECT NAME: Lakewood Ranch Master Lift Station
PROJECT NUMBER: 404-606781
SECTION/TWNSHP/RANGE: 20-35-19
PROJECT DESCRIPTION: Rehab wetwell and piping for lift station
PROJECT SITE DIMENSIONS: All work is within the lift station parcel

LIFT STATION

ITEM NO.	DESCRIPTION	UNITS	QTY.	UNIT PRICE (\$)	EXTENDED PRICE (\$)
1	4" x 8" DI Eccentric Reducer, FLG	EA	5		
2	By-Pass Pumping	LS	1		
3	Spraywall Liner (Repair) – Wet Well	SF	100		
4	Drain Down & Clean Wet Well	LS	1		
5	Remove Base Ells, Anchors, Piping, Valves, Bracing, Supports	LS	1		
6	8" SCH 10 S. S. (.316L) Piping W/Welded SS Flanges	LF	80		
7	4" Pump Base Ells & Base Plates (Grinding/Leveling and Grout As Req'd)	EA	5		
8	EBBA Series 2100 Mega Flange Restrained FLG Adapter or Approved Equal	EA	15		
9	8"- 90 Degree Bend, SCH 10 SS (316L) w/Welded SS	EA	5		
10	S.S. Adjustable Pipe Support	EA	5		
11	8" Swing Check Valve	EA	5		
13	Install 1/4" x 2 S.S. (304) Pipe Bracing System	EA	10		
14	DI Fittings	LB	100		
15	Retain/Reinstall Exist. S. S. Pump Guide Rail System	LF	5		
16	Install New Linkseal at WW Wall for SCH 10 SS Piping	EA	5		
17	Asphalt Driveway Repair: Remove & Replace Inc. Subgrade	SY	18		
18	Mobilization (Max 10% of Total Bid)	LS	1		
19	Miscellaneous Work & Clean Up (% of Sub Total)	LS	1		
20	Discretionary				\$ 15,800.00
TOTAL BID PRICE					

Acknowledged Addendum No. _____ Dated _____
 BIDDER _____