

MEMORANDUM

To: All Interested Bidders

Date: May 19, 2016

Invitation for Bid IFB 16-16160V

Subject: Manatee County Central Library, Exterior Lighting,
1301 1st Avenue West, Bradenton, FL 34205

ADDENDUM #4



Bidders are hereby notified that this Addendum shall be acknowledged on Bid Form Page 00300-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without Acknowledgement of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding document, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

The deadline of May 13, 2016 to submit all inquiries concerning interpretation, clarification or additional information pertaining to this bid has expired. This deadline has been established to maintain fair treatment for all potential bidders, while maintaining the expedited nature of the Economic Stimulus that the contracting of this work may achieve.

If you have submitted a bid prior to receiving this addendum, you may request in writing that your original sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

Questions received from bidders through May 13, 2016:

Q1. At the N.E. Corner, facing north, for the L2 fixtures, do you want individual fixtures as shown or do you want a continuous strip with no breaks? These fixtures can be joined together for a row or mounted individually. If mounted individually each fixture will need its own power pack and its own penetration. Same for the runs going down the East side of the building.

A1. For the entire area, please see the new drawing EX1 for the North and East sides. This shows the continuous run with a possible connection with a junction box and conduit. The junction box and conduits should be painted (for example: Krylon to bond to metal and PVC, and not flake) to match per the plans. A continuous run can be made with multiple lengths of fixtures. The fixtures come in a variety of lengths.

Q2. Again, at the N.E. Corner facing north, the fixture mounting height is shown as 6" below the roof line. It appears this will put the fixtures in the existing sign. Also, not knowing the depth of the actual roof deck this may put us lower than 6". Please advise.

Financial Management
Purchasing Division
1112 Manatee Ave W Suite 803, Bradenton, FL 34205
Phone number: (941)749-3014

May 19, 2016
Invitation for Bid IFB16-16160V
ADDENDUM #4 / Page 2 of 2

A2. See the new drawing EX1. We looked at the mounting and the space between the letters and the top of the roof. The mount should not be on the sign at all. You will need to seal the penetrations made with the mounting. Conduits and a junction box may be used on the outside if they are painted (for example Krylon to bond to PVC and metal, and not flake) to match the exterior colors.

Bids will be received at the Manatee County Purchasing Division, 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205 on **June 2, 2016 at 3:00 PM.**

End of Addendum #4

Sincerely



Melissa M. Wendel, CPPPO, Purchasing Official
Manatee County Purchasing Division

Ov

(1) Pdf attachment: Drawing EX1 for the North and East side of Library (1 total page)