



1112 Manatee Avenue West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

### Solicitation Addendum

---

Addendum No.:	2
Solicitation No.:	21-TA003651DJ
Project No.:	6041587
Solicitation Title:	Holmes Boulevard Force Main Replacement
Addendum Date:	April 16, 2021
Procurement Contact:	Dave Janney Senior Procurement Agent

**IFBC 21-TA003651DJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 21-TA003651DJ.**

### UPDATE:

### SECTION C, BID ATTACHMENTS, BID ATTACHMENT 3, PLANS, PLAN SHEET 7.

There were no changes to Plan Sheet 7 and not included in Addendum 1.

### QUESTIONS AND RESPONSES:

- Q1**      **Reference question 64: There Is no FDOT Certified crushed concrete available for purchase in the market place. Will optional FDOT certified base material be acceptable?**  
**I understand crushed concrete is the product of choice, and we can obtain it that meets the specs but not FDOT certified.**
- R1.**      Under Manatee County standards, certified FDOT crushed concrete base material is required. There is FDOT-certified crushed concrete base material currently available in Punta Gorda.
- Q2.**      **There are 2 pay items for a permit fee as an allowance.**  
**Will these items cover the water service permits for the backflow preventors?**  
**Or must separate permit fees be included for each service?**  
**If so, Please provide the permit cost as needed.**

R2. If permit fees exceed the allowance, additional required permit fees will be taken out of project contingency.

**Q3. Just need clarification if these 2 allowance covers each service connection. R43 states we are to pay for EACH plumbing permit leading one to believe this may be in addition to the allowances.**

R3. Refer to R2.

**Q4. In Attached Addendum 1 for this job section C says to replace plan sheets 7-18 but the new plan sheets sent out are only 8-18, is plan sheet 7 being removed, staying the same, or will there be a new plan sheet sent out?**

R4. There were no changes to Plan Sheet 7 and not included in Addendum 1.

**NOTE:**

Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFBC.

**INSTRUCTIONS:**

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

**END OF ADDENDUM**

AUTHORIZED FOR RELEASE