



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 2
Solicitation No.: 24-TA005050LP
Project No.: 6117680
Solicitation Title: Upper Manatee River RD RTU #330 Rehabilitation
Addendum Date: January 10, 2024
Procurement Contact: Leslie Peer

IFBC 24-TA005050LP is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 24-TA005050LP

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was January 5, 2024

QUESTIONS AND RESPONSES:

Q1. The existing service appears to be 200 Amps. The existing ATS appears to be 400 Amps. What size should the new service and ATS be?

R1. The ATS would need to be 200 Amps. It must have been oversized when it was installed.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE