



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 4
Solicitation No.: 24-TA004989DJ
Project No.: 6109670
Solicitation Title: LMWTP Sedimentation Basin C Sludge Collection Upgrade
Addendum Date: January 8, 2024
Procurement Contact: Dave Janney, Procurement Agent III

IFBC 24-TA004989DJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 24-TA004989DJ.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was December 15, 2023.

QUESTIONS AND RESPONSES:

Q1. Will the electrical contractor be responsible for installing the control panel on the new bridge?

R1. No, it will come installed on the bridge.

Q2. Will the electrical contractor be responsible for installing the new festoon cables?

R2. Yes, the cable will be provided by OVIVO and installed by the contractor onto the existing festoon system.

Q3. Will the electrical contractor be responsible for installing any conduit or cables on the new bridge between the control panel and equipment or devices on the new bridge?

R3. Everything on the bridge will come prewired to the junction box, the contractor will need to make the connection from the junction to the festoon supports.

Q4. Are the existing conduits and cables for the existing disconnects to be demolished?

R4. Yes

Q5. Can these conduits be reused?

R5. No.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE