



1112 Manatee Avenue West

Bradenton, FL 34205

purchasing@mymanatee.org

Solicitation Addendum

Addendum No.:	1
Solicitation No.:	21-TA003622SAM
Project No.:	402-0019707
Solicitation Title:	Satellite Lift Station R&R 2020 Group 3
Addendum Date:	February 19, 2021
Procurement Contact:	Sherri Meier

IFBC No. 21-TA003622SAM is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of IFBC No. 21-TA003622SAM.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was February 12, 2021.

CHANGE TO:

SECTION A, INFORMATION FOR BIDDERS, PUBLIC OPENING OF BIDS, A.03

Bids will be opened immediately following the Due Date and Time at the Manatee County Administration Building, Suite 803 in the presence of County officials. Bidders or their representatives may attend the Bid opening virtually by accessing the link below.

Zoom® Webinar Link: <https://manateecounty.zoom.us/j/85938125087>

Manatee County will make public at the opening the names of the business entities which submitted a Bid and the total bid price submitted. No review or analysis of the Bids will be conducted at the Virtual Bid Opening.

REPLACE:

SECTION C, BID ATTACHMENTS, BID ATTACHMENT 3, PLAN SHEET NUMBERS 4, 5, 6, 8, AND 9

Replace Bid Attachment 3 Plan Sheet numbers 4, 5, 6, 8, and 9 with revised Plan Sheet numbers 4, 5, 6, 8, and 9 issued as a separate attachment with this Addendum 1.

Clarifications of Engineer's Changes:

Plan Revisions

Sheet 4 –

General Notes:

1. Proposed, removed Note 4, “All existing ductile iron pipe and/or fittings labeled to remain in the valve vault shall be coated with a bituminous coating.”
2. Proposed, edited note 5, removed, “exterior and”.
3. Renumbered notes.

Proposed, added 2' Max dimension between valve vault an isolation valve.

Proposed, fix control panel illustration.

Sheet 5 –

Existing, revised approximate location of control panel, tower, and water service.

Proposed, revised approximate location of control panel, removed tower.

Sheet 6 –

Proposed, revised approximate location of control panel.

Proposed, remove stilling well from elevation view.

Sheet 8 –

Proposed, revised control panel callouts.

Proposed, added stilling well to plan and elevation views.

Sheet 9 –

Added dimension between wet well and pump.

Specifications:

None.

Bid Form:

None.

QUESTIONS AND RESPONSES:

Q1. Is there an engineer estimate for this work?

R1. Yes, the engineers estimated opinion of cost is \$1,109,000.00.

Q2. Can you confirm that the bid date and time for the project is still 03/03/21 at 2:00 PM?

R2. Yes, that is the correct date and time of the bid opening.

Q3. Are there any new addendum for the project available?

R3. Addendum 1 is the only addendum issued at this time.

NOTE:

Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM 1

AUTHORIZED FOR RELEASE