



1112 Manatee Ave. West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 3
Solicitation No.: 18-TA002587DC
Solicitation Title: Force Main 11 Replacement
Project No.: N/A
Addendum Date: December 11, 2017
Procurement Contact: Deborah Carey-Reed

INVITATION FOR BID (IFB) 18-TA002587DC IS AMENDED AS SET FORTH HEREIN. RESPONSES TO QUESTIONS POSED BY PROSPECTIVE BIDDERS ARE PROVIDED BELOW. THIS ADDENDUM IS HEREBY INCORPORATED IN AND MADE A PART OF IFB 18-TA002587DC.

Change to:

BID OPENING TIME AND DATE DUE:

BID OPENING TIME AND DATE DUE: December 19, 2017.

Change to:

DEADLINE FOR CLAIRIFICATION REQUESTS:

DEADLINE FOR ADDENDUM 3 CLARIFICATION REQUESTS: December 13, 2017.

Add:

BID FORM – EXCEL VERSION

A Microsoft Excel® electronic version of the Bid Form has been posted with this solicitation. Bidders are encouraged to use the electronic version. There are no item revisions.

Questions and Responses:

- Q1. It appears to us that the butt fused connection in the wet well is not feasible. Please clarify.
R1. The intent for the butt fused connection is to be made when the station is on bypass. The contractor will remove the existing riser pipe and butt fuse the extension outside the wet well.
- Q2. Reference Addendum Two, plan sheet 17, what is the thickness of the proposed concrete slab beneath the piping and valves assembly?
R2. The thickness of the proposed slab shall be 6-inches.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added. All other terms and conditions remain as stated in the IFB.

End of Addendum

INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE: 