



# MANATEE COUNTY

November 16, 2010

All Interested Bidders:

SUBJECT: Invitation for Bid #10-3612-OV  
Lincoln Park Splash Pad & Restroom Pavilion  
501 17<sup>th</sup> Street East, Palmetto, FL

## ADDENDUM #2

**Bidders are hereby notified that this Addendum shall be acknowledged on page 00300-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete.**

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

**Bidders Note:** The deadline for clarification requests was November 5, 2010, 5:00 PM. Questions received after the date shall not be considered.


**Attached :** Ugarte & Associates, Inc. Memorandum dated November 16, 2010 providing clarification of Addendum#1, RFI Answer #4.

If you have submitted a bid prior to receiving this addendum, you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

## END OF ADDENDUM #2

Bids will be received at the **Manatee County Purchasing Division, 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205 until 3:30 P.M. on November 19, 2010.**


Sincerely,

  
R. C. "Rob" Cuthbert, C.P.M, CPPO  
Purchasing Division Manager  
Ov (1 total page att.)

Financial Management Department – Purchasing Division  
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205  
Phone: 941-708-7527 – Fax: 941-708-7544

LARRY BUSTLE \* DR. GWENDOLYN Y. BROWN \* JOHN R. CHAPPIE \* RON GETMAN \* DONNA G. HAYES \* CAROL WHITMORE \* JOE MCCLASH

District 1      District 2      District 3      District 4      District 5      District 6      District 7



**UGARTE & ASSOCIATES, INC.**  
ARCHITECTURE • PLANNING

434 9<sup>TH</sup> AVENUE WEST • PALMETTO, FLORIDA 34221  
p: (941) 729-5691 • f: (941) 729-5692

**MEMORANDUM**

TO: Olga Valcich, Manatee County Purchasing Department  
CC: Howard Leyo, Manatee County Project Management  
FROM: David Bishop, Project Manager  
DATE: November 16, 2010  
RE: Addendum #2  
IFB #10-3612-OV Lincoln Splash Pad and Restroom Pavilion

**CLARIFICATION OF ADDENDUM #1 RFI ANSWER #4:**

Based on the information provided by Water Park Features, Inc., we are unable to determine the compatibility of its product with the product in the Invitation for Bid.

The Rain Drop "Omni Pod" System was requested by the Parks and Recreation Department specifically to rotate and interchange vertical splash features between the new splash pad at Lincoln Park and the existing splash pad at Pride Park. Specific specifications to reference for compatibility requirements are Sheet PL1.10 "Activities List" and Sheet PL1.11, Detail #2.

Should the Bid submitted claim to meet the criteria of the Invitation for Bid, further documentation of the compatibility of the product will be required in order that the Splash Pad Engineer may perform a thorough evaluation of the proposed offering to ensure that the product meets or exceeds the stated specification.