



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 3
Solicitation No.: 22-TA004045JH
Project No.: 402-0019707
Solicitation Title: Satellite Lift Station R&R 2022 Group 1
Addendum Date: April 26, 2022
Procurement Contact: Jeb Hayter

IFBC 22-TA004045JH is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 22-TA004045JH.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was April 1, 2022.

QUESTIONS AND RESPONSES:

- Q1. The pump vendor was asking if the horsepower will be changing at the stations, we didn't see where it was indicated either way?**
- R1. The exact pumps will be removed and replaced back in each wet well after each rehab with the following data. Harbor Woods – 5 HP, 230 volt, 3 phase; Bolletieri park – 25 HP, 230 volt, 3 phase; Kay Road – 7.5 HP, 230 volt, 3 phase; Palm Aire 3 – 15 HP, 230 volt, 3 phase; Palm Aire 6 – 3 HP, 230 volt, 3 phase; Ridgewood 1 – pumps are hydro S4M1500, 15 HP 8.38 impeller, 230 volt, 3 phase.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE