



MANATEE COUNTY

April 9, 2012

All Interested Bidders:

SUBJECT: Invitation for Bid #12-1144-OV
Second 10 MG Reclaimed Water Storage Tank and High Service Pump Station
At the Southwest Water Reclamation Facility
Manatee County Project No. 6037083

ADDENDUM #2

Bidders are hereby notified that this Addendum shall be acknowledged on page 00300-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

The stated deadline of March 27, 2011 to submit all inquiries concerning interpretation, clarification or additional information pertaining to this bid has lapsed. This deadline has been established to maintain fair treatment for all potential bidders, while maintaining the expedited nature of the Economic Stimulus that the contracting of this work may achieve. Questions received after this date and time shall not be considered.

Bidders Note: Clarification is made to the following question / answer provided in Addendum #1:

Question: "In order to insure competitive bidding on the new storage tank, Precon asks that we be allowed to bid on the existing tank modifications and assume the remaining warranty for the existing tank."

Answer: The existing tank modifications shall include Precon Corporation as an acceptable tank construction company provided PreCon fully assumes the remaining warranty for the existing tank which would include complete, unconditional warranty as stated in **Section 13200-3, Prestressed Concrete Tank, Article 1.05 Quality Assurance, subcategory "E", Existing Tank Modifications and Article 1.06 Warranty.**

Financial Management Department - Purchasing Division
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
Phone: 941-749-3055 - Fax: 941-749-3034

LARRY BUSTLE * MICHAEL GALLEN * JOHN R. CHAPPIE * ROBIN DISABATINO * DONNA G. HAYES * CAROL WHITMORE * JOE McCLASH
District 1 District 2 District 3 District 4 District 5 District 6 District 7

April 9, 2012

Invitation for Bid #12-1144-OV

Second 10 MG Reclaimed Water Storage Tank and High Service Pump Station

At the Southwest Water Reclamation Facility

Manatee County Project No. 6037083

Page 2 / Addendum #2

Bidders Note: Pursuant to Specification Section 11100 Pumping Systems: Additional information is provided to all Bidders:

Section 11100 – Pumping Systems: Article 1.03, Page 11100-2 – Manufacturer and Quality Assurance Requirements: Add subcategory E and F.

E. Pump manufacturer shall have a minimum of three (3) similar type pump installations (i.e.; pump type, pumping rate and motor horsepower) in the State of Florida. References shall be supplied as part of the Contractor's bid.

F. Pump manufacturer shall maintain a certified pump repair center within 150 miles of the project site. Location information shall be supplied as part of the Contractor's bid.

If you have submitted a bid prior to receiving this addendum, you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

END OF ADDENDUM #2

Bids will be received at the **Manatee County Purchasing Division, 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205** until **2:00 P.M. on April 18, 2012 at 2:00 PM.**

Sincerely,



Melissa M. Wendel, CPPO, Purchasing Official
Purchasing Division

DMW

Ov