



MANATEE COUNTY FLORIDA

June 3, 2009

TO: All Interested Bidders

SUBJECT: **Invitation for Bid # 09-1822-DS**
Water Main Installation- 51st Street West from Cortez to 53rd Avenue
(Cortez Road / Glen Lakes), Bradenton, FL

ADDENDUM # 3

Bidders are hereby notified that this Addendum shall be acknowledged on pages 00300-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

1. Attachment: Manatee County, Memorandum, dated June 3, 2009, (1) page.
Subject of Memorandum: 51st Street W. Waterline Project 6031970—Response to Bidders Questions

If you have submitted a bid prior to receiving this addendum, you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

THIS ADDENDUM MUST BE ACKNOWLEDGED ON THE BID FORM FOR YOUR BID TO BE CONSIDERED RESPONSIVE.

END OF ADDENDUM # 3

Finance Management Department
Mailing Address: Purchasing Division: 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
PHONE: 941-749-3045 * FAX: 941-749-3034
www.mymanatee.org

Page 2
June 3, 2009
IFB# 09-1822-DS
ADDENDUM # 3

Bids will be received at the Manatee County Purchasing Division, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until 2:00 P.M. on June 16th 2009.

Sincerely,

R. C. "Rob" Cuthbert, CPM, CPPO
Purchasing Division Manager
Enclosure
/ds

Finance Management Department
Mailing Address: Purchasing Division: 1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205
PHONE: 941-749-3045 * FAX: 941-749-3034
www.mymanatee.org

LARRY BUSTLE * DR. GWENDOLYN Y. BROWN * JOHN R. CHAPPIE * RON GETMAN * DONNA G. HAYES * CAROL WHITMORE * JOE MCCLASH
District 1 *District 2* *District 3* *District 4* *District 5* *District 6* *District 7*

MEMORANDUM



PUBLIC WORKS DEPT.
Engineering Division
4422B 66th Street West
Bradenton FL 34210,

MANATEE COUNTY
FLORIDA

Phone: 941.792.8811
Fax: 941.795.3467
www.myanatee.org

To: Mike O'Reilly, Project Manager
From: Jim Stockwell, Senior Project Engineer
Date: June 3, 2009
Subject: 51st Street W. Waterline Project 6031970 - Response to Bidders Questions

Mike:

I received the following questions from Jack Morsink of Westra Construction regarding this project today, via. Donna Stevens:

1. It appears that with the bid quantity of 224 each of 16" Pipe Joint Restraints that the entire run of open cut pipe must be restrained. Is that truly the intent?
2. There is no pay item for the 18" x 16" tapping sleeve. Will one be added?
3. I understand the pay item for the swing check valves will be deleted and a revised bid schedule will be issued. Do you know when this addendum will be issued?

My responses are:

1. There may be significant areas of somewhat soft soil conditions so it was assumed that restraint of all pipe joints may be necessary. As pipe is installed, particularly on the north half, if good soil conditions are encountered, then some restraints may be eliminated in accordance with our standards. The contractor will be paid for the actual quantity of restraints installed.
2. The pay item for the 18x16 tapping sleeve is being added and the pay item for check valves is being deleted by the addenda, which I believe have been or will soon be issued.

Please let me know if you need further clarification or information regarding these questions.

Sincerely,

Handwritten signature of James Stockwell in cursive.

James Stockwell, PE
Senior Project Engineer

Cc: Donna Stevens, Construction Buyer

M:\Engineering\Projects\~WATER LINE Projects\51st St W Waterline\Docs\BidderQResponse060309.doc

4422 B 66th Street West * PHONE: (941) 792-8811 * FAX: (941) 795-3467
Manatee County Public Works Department/Infrastructure Engineering Division * www.myanatee.org