



1112 Manatee Avenue West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

---

Addendum No.: 1  
Solicitation No.: 24-R085102JK  
Solicitation Title: Basketball Courts at Bunker Hill Park  
Addendum Date: July 23, 2024  
Procurement Contact: Julie Kovacs

**Invitation to Quote No. 24-R085102JK is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of Invitation to Quote No. 24-R085102JK.**

**The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this Invitation to Quote is July 17, 2024.**

### QUESTIONS AND RESPONSES:

**Q1. Per your attachment G, quote form. Item # 3, states provide and level 5 ½ in of crushed concrete base.**

**That is not a good base to use, we use DOT approved standard base. In our 40 years of experience, we know not to use crushed concrete under asphalt, we strongly advise against this. Below I will list the benefits of using DOT standard base.**

**The base materials used in Florida Department of Transportation (FDOT) construction can vary based on the specific project requirements. Here are some of the optional base materials allowed by FDOT but not limited to: Additionally, some materials are restricted to non-limited access paved shoulders or other non-traffic bearing applications.**

- 1. Lime rock: Available in thicknesses ranging from 4 inches to 8.5 inches.**
- 2. Cemented Coquina: Similar thickness options as lime rock.**
- 3. Shell Rock: Also available in various thicknesses.**
- 4. Bank Run Shell: Thicknesses from 4 inches to 8.5 inches.**

R1. OK to quote using your recommended best practices for this job.

**NOTE:**

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the Invitation to Quote.

**INSTRUCTIONS:**

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

**END OF ADDENDUM**

AUTHORIZED FOR RELEASE