



Financial Management Department
Purchasing Division
1112 Manatee Ave W Suite 803
Bradenton, FL 34205
Phone: (941) 749-3014
www.mymanatee.org

August 14, 2014

TO: All Interested Bidders
SUBJECT: Invitation for Bids #14-2032CD
10 MG Storage Tank and Interconnection at the Southeast Water Reclamation Facility

ADDENDUM #3

Bidders are hereby notified that this Addendum shall be acknowledged on page Bid Form-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgment of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

1. CLARIFICATION of Revised Plan Sheet M-3.2 issued with Addendum #2:

- Provide 4" ARV as directed in Addendum #1.
- Remove 6" BFV and 20" x 6" TEE Callouts from Section B/M-3.1 on Revised Plan Sheet M-3.2 and Replace with 4" BFV and 20" x 4 TEE.
- Remove 6" BFV, (2) 6" 90° FL BENDS and 12" x 6" TEE Callouts from Section C/M-3.1 on Revised Sheet M-3.2 and Replace with 4" BFV, (2) 4" 90° FL BENDS and 12" x 4" TEE.

The following question has been presented by a potential by the Deadline for Clarification Requests:


QUESTION #1: The pump section 11313 does not list any coatings required for the pumps. Will the county want to have any coatings applied? Also no safety guards are listed, will the county want safety guards on the pumps?

RESPONSE #1: Please refer to Article 1.02.C.1 of Section 11313 for coatings requirements. All new pumps shall have coupling guards.

END OF ADDENDUM #3

Bids will be received at Manatee County Purchasing, 1112 Manatee Avenue West, Bradenton, Florida 34205 until **Wednesday, August 20, 2014 at 3:00 PM.**

Sincerely,



Melissa M. Wendel, CPPO
Purchasing Official