



1112 Manatee Ave. West  
Bradenton, FL 34205  
purchasing@mymanatee.org

## Solicitation Addendum

---

**Addendum No.:** 3  
**Solicitation No.:** 17-2001OV  
**Project No.:**  
**Solicitation Title:** Chiller and Exhaust Fan Replacement at the Water treatment Lab  
**Addendum Date:** October 26th, 2017  
**Procurement Contact:** Olga Valcich olga.valcich@mymanatee.org

---

**IFB NO. 17-2001OV IS AMENDED AS SET FORTH HEREIN. RESPONSES TO QUESTIONS POSED BY PROSPECTIVE BIDDERS ARE PROVIDED BELOW. THIS ADDENDUM IS HEREBY INCORPORATED IN AND MADE A PART OF IFB NO. 17-2001OV CHILLER AND EXHAUST FAN REPLACEMENT AT THE WATER TREATMENT LAB.**

Replace the following Plan Sheets:

**PLAN SHEET CH-M3.1 MECHANICAL DETAILS**

- "New water Pump schedule": Revised pump Selection CHWP-1. Motor remain unchanged.
- "New water Pump schedule": Note added to clarify connection of new pump to existing piping
- "Buffer Tank Schedule": Note added to clarify that chilled water supply and return piping connections on buffer tank, shall match line size, 4".

**PLAN SHEET CH-E2.0 ELECTRICAL CHILLER YARD RENOVATION PLAN**

- Revised keynote 6 to specify replacing existing 600A 'MDP' panelboard with new panelboard.

**PLAN SHEET CH-E3.0 ELECTRICAL RISER DIAGRAM & SCHEDULES**

- Revised panel schedules and riser diagram to show existing 'MDP' panelboard replaced with new panelboard.

Change: BID OPENING DATE DUE: 3:00 PM on ~~October 31, 2017~~ November 3, 2017.

---

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added. All other terms and conditions remain as stated in the Invitation for Bid.

### End of Addendum

#### INSTRUCTIONS:

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.