



1112 Manatee Avenue West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

---

Addendum No.: 1  
Solicitation No.: 21-TA003854AJ  
Project No.: 6016080  
Solicitation Title: In-Situ Grit Removal Southeast Water Reclamation Facility (SEWRF) Capacity Improvements Project  
Addendum Date: October 15, 2021  
Procurement Contact: Abby Jenkins

**IFBC No. 21-TA003854AJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 21-TA003854AJ.**

**The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was October 12, 2021.**

### QUESTIONS AND RESPONSES:

**Q1. What is the Engineer/Budget/Project opinion of cost?**

R1. The opinion of cost is \$990,000.00.

**Q2. Following the bid date, what is the County's expected timeframe to issuance of an NTP?**

R2. Notice to Proceed (NTP) is issued after the Agreement has been fully executed.

**Q3. Given that the grit is to be removed while the tanks are in operation, which would seem to present little to no interruption to plant processes, what is the reason for a 180-calendar day timeframe for performance?**

R3. The County needs the grit removed to improve the operation of the biological treatment process and restore the capacity of the tanks ahead of the next wet season.

**Q4. What is the purpose of requiring two (2) projects with at least 2,000 CY removed? There are not many projects performed in this industry that meet that threshold and it may have the effect of limiting competition from otherwise qualified bidders. If the County will not reconsider this requirement will it consider accepting more references which would display competency removing large quantities from tanks while in operation?**

R4. To demonstrate that a bidder has the ability to complete a large project in a timely and efficient manner.

**NOTE:**

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

**INSTRUCTIONS:**

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

**END OF ADDENDUM**

AUTHORIZED FOR RELEASE