



Financial Management Department
Purchasing Division
1112 Manatee Ave W Suite 803
Bradenton, FL 34205
Phone: (941) 749-3014
www.mymanatee.org

August 19, 2014

TO: All Interested Bidders
SUBJECT: Invitation for Bids #14-2032CD
10 MG Storage Tank and Interconnection at the Southeast Water Reclamation Facility

ADDENDUM #4

Bidders are hereby notified that this Addendum shall be acknowledged on page Bid Form-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgment of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

1. **CHANGE** Article 2.01.A of Section 15100 on page 15100-2 of the Technical Specifications to read as follows:

Butterfly valves (4" thru 48" size) shall conform to the AWWA Standard Specifications for Rubber Seated Butterfly Valves, Designated C504, except as hereinafter specified. Valves shall be Class 250B, and equal to those manufactured by Henry Pratt Company, DeZurik, Mueller, KOR-FLO or approved equal. All valves shall be factory leak tested at 250 psi.

2. **CHANGE** Article 2.01.F of Section 15100 on page 15100-3 of the Technical Specifications to read as follows:

All valves shall be subject to hydrostatic and leakage tests at the point of manufacture. The Class 250 valves shall be tested in conformance with AWWA C504. During the hydrostatic test there shall be no leakage through the metal, the end joints or the valve shaft seal. No adjustment of the valve disc will be necessary after pressure test for normal operation of valve.

3. **CLARIFICATION** of Note #2 of the Utility Notes on Plan Sheet G-0.2:

The latest version of the Manatee County Utility Standards is included by reference. When a conflict exists between the Manatee County Utility Standards and the Technical Specifications or Plans, the Manatee County Utility Standards shall take precedence.

August 19, 2014

4. **CHANGE** the Due Date and Time to **Friday, August 22, 2014 at 3:00 PM.**

END OF ADDENDUM #4

Bids will be received at Manatee County Purchasing, 1112 Manatee Avenue West, Bradenton, Florida 34205 until **Friday, August 22, 2014 at 3:00 PM.**

Sincerely,

A handwritten signature in black ink that reads "Melissa M. Wendel" with a long horizontal flourish extending to the right. Below the flourish, the word "for" is written in a smaller, cursive script.

Melissa M. Wendel, CPPO
Purchasing Official