



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 4
Solicitation No.: 21-TA003718AJ
Project No.: 6097880
Solicitation Title: Force Main 33A and 36A Replacements
Addendum Date: September 8, 2021
Procurement Contact: Abby Jenkins

IFBC 21-TA003718AJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 21-TA003718AJ.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC was July 23, 2021.

QUESTIONS AND RESPONSES:

Q1. The provided specification for the Plug Valve states that the valve body, bonnet, and gland shall be ASTM A-126 Cast Iron or ASTM A-526 Grade 65-45-12 Ductile Iron Per AWWA C-517. Please confirm that either is acceptable because there is a significant price/lead time difference between the two.

R1. Either of the specifications will be acceptable.

NOTE:

Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE