

**ATTACHMENT K, SAMPLE BACKFLOW PREVENTION ASSEMBLY TEST AND
MAINTENANCE REPORT FORM**



Backflow Prevention Assembly Test and Maintenance Report Form
Manatee County Utilities Department

This Report Produced By

Manatee County Utilities Department

Customer Information

Customer Name: OUR CUSTOMER

Address: 123 MAIN ST BRADENTON FL 34210-2736

Premise Number: 1234

Meter Number: 12345678

Backflow Prevention Device Information

Serial Number: 12345678

Line Size: 0.75

Line Type: potable

Manufacturer: WILKINS

Model: 975XL

Location: NW CORNER

Test Results

Test Date: Jan 11, 2021

Tester's Certification: B11-19-XXXXX

Tester's Company: COMPANY NAME

Valve Type Code: RPV

Relief Valve PSI: 2.5

Valve 1 PSI: 7.3

Valve 2 PSI: 2.0

Test Result: PASSED

Repairs, Parts, Materials & Components: CHECK DISK AND SEAT IN CV2

Next Test Date: Jan 11, 2022