



Financial Management Department  
Procurement Division  
1112 Manatee Ave W Suite 803  
Bradenton, FL 34205  
Phone: (941) 749-3074  
[www.myanatee.org](http://www.myanatee.org)

Email

September 6, 2017

TO: All Interested Bidders

SUBJECT: Invitation for Bid (IFB) 17-0418DC  
45<sup>th</sup> Street Roadway Improvements  
ADDENDUM 10

Bidders are hereby notified that this Addendum shall be acknowledged on the Bid Form and made a part of the above named bidding and contract documents.

The following items are issued to add to, modify, and/or clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

1. Question: Addendum 8 Question 19 asked what the agreement was with FP&L in regards to the overhead power lines and the need to drive concrete piling directly underneath... The response states that we are to coordinate with FP&L. Please re-visit this problem and concern and advise us as to the solution.

**Response:** A temporary relocation plan for the overhead electric line has been discussed with FPL. The overhead electric line will be temporarily relocated to the west side of 45<sup>th</sup> Street at the bridge location and then set to the final location after the construction of the pedestrian bridge. The contractor will coordinate with FPL to discuss the timing of the relocations and possible alternative relocation plans during construction.

If you have submitted a bid prior to receiving this addendum you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

Bids will be received at Manatee County Procurement, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until **September 12, 2017 at 3:00 P.M.**

Sincerely,

Chris Daley, CPPO, CPPB  
Contracts Specialist Manager  
/dcr