



December 18, 2015

TO: All Interested Bidders

SUBJECT: ADDENDUM #4 – IFB #15-1599BLS
Sanitary Sewer Systems, Stormwater Systems, Line and Manhole
Rehabilitation Services (as required)

REVISED - Invitation for Bid Due Date: January 7, 2016 at 3:00PM

Bidders are hereby notified that this addendum shall be acknowledged within their bid and shall be made a part of the above issued Invitation for Bid. This information is issued to add to, modify, and/or clarify the Invitation for Bid documents. These items shall have the same force and effect as the original Invitation for Bid. Bids are to be submitted on the specified date and shall conform to the additions and revisions listed herein.

QUESTION #1: Ref: Group 1 Section C: Lines 5, 6 & 7
Trenchless lateral cleaning and reconstruction and Full wrap at main.
Since a separate Group (Group 4) has been added to address lateral reconstruction (lining), should lateral reconstruction/wrap, not be deleted from Group1 or do these line items pertain to another repair methodology?

ANSWER: Group four is for lateral lining and Group one is for main line lining.

QUESTION #2: Ref Group 1 Section D:
Sanitary Sewer Grouting Page 22 of Supplemental Technical Specifications;
Specifications call for AV118, AV100 or an approved equal. Will Manatee County accept AV254 Urethane?

ANSWER: No, AV254 Urethane Grout is not an approved product with Manatee County; (reference Supplemental Technical Specifications, dated November 2015, Section 02763, Chemical Grouting).

Page Two
December 18, 2015
Addendum #3, IFB #15-1599BLS
Sanitary Sewer Systems, Stormwater Systems,
Line and Manhole rehabilitation Services (as required)

QUESTION #3: **Ref: Group 2 Section A:**
Repair Sleeve Trenchless Pipe Reconstruction (CIPP) Page 26 of
Supplemental Technical Specifications.
Will Manatee County accept an approved equal sectional liner such as
Magnaline (Fiberglass & Epoxy based)?

ANSWER: No, Magnaline (Fiberglass & Epoxy based) liners has a mill thickness that is too
thin for Manatee County specifications; (reference Supplemental Technical
Specifications, dated November 2015, Section 02626, Sanitary Sewer Lateral
Rehabilitation).


Dennis Wallace
Contracts & Buyer Manager


Date

dww/bls