



# MANATEE COUNTY

December 30, 2008

TO: All Interested Bidders

SUBJECT: Invitation for Bid #09-0192-OV  
Improvements to Master Lift Station 41-A

## ADDENDUM #2

**Bidders are hereby notified that this Addendum shall be acknowledged on page 00300-1 of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgement of the Addendum will be considered incomplete.**

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

Based upon instructions from Rebecca Avalos, Project Engineer, Water / Wastewater Group for URS Corporation.

The Plans and Specifications for the subject project shall be clarified, supplemented and/or amended as follows:


- One (1) page attached. This is in response to Question(s) received on December 29, 2008.

**THIS ADDENDUM MUST BE ACKNOWLEDGED ON THE BID FORM OF YOUR BID.**

**END OF ADDENDUM #2**

Bids will be received at the Manatee County Purchasing Division, 1112 Manatee Avenue West, Bradenton, FL 34205 until **2:00 P.M. on January 8, 2009.**

Sincerely,

  
R. C. "Rob" Cuthbert, CPM, CPPO  
Purchasing Division Manager

Financial Management Department – Purchasing Division  
1112 Manatee Avenue West, Suite 803, Bradenton, FL 34205  
Phone: 941-749-3014 – Fax: 941-749-3034

FARRY BUSTLE \* DR. GWENDOLYN Y. BROWN \* JOHN R. CHAPPIE \* RON GETMAN \* DONNA G. HAYES \* CAROL WHITMORE \* JOE  
MCCLASH

District 1                      District 2                      District 3                      District 4                      District 5                      District 6                      District 7



# Memorandum

Date: December 30, 2008

To: Olga Valcich, Manatee County Purchasing Department

Cc: Chuck Froman, Manatee County Project Management

From: Rebecca Avalos

Subject: **Text for Addendum No. 2**  
**MLS 41A (6066480) IFB 09-0192OV**

## Response to Questions

### Questions from Beach Construction, submitted 12/29/08 via email

Question 1: I have a question about the generator fuel tank shown on Sheet M-1. The Notes on the right hand side refer to the tank as a sub-base fuel tank. However, the drawings show a separate fuel tank. Is there more than one 1,000 gallon fuel tank- one beneath the generator and one to the left of the generator?

Response 1: There is one fuel tank, an aboveground 1,000 gallon tank located adjacent to the generator. There is no sub-base fuel tank.