

Financial Management Department Purchasing Division 1112 Manatee Ave W Suite 803 Bradenion, FL 34205 Phone: (941) 749-3074

<u>Email</u> March 29, 2017

TO: All Interested Bidders

SUBJECT: Invitation for Bid (IFB) #17-0772GC Force Main 5 Replacement

ADDENDUM 4

Bidders are hereby notified that this Addendum shall be acknowledged on page <u>Bid Form-1</u> of the Bid Form and made a part of the above named bidding and contract documents. Bids submitted without acknowledgment of the Addendum will be considered incomplete.

The following items are issued to add to, modify, and clarify the bid and contract documents. These items shall have the same force and effect as the original bidding and contract documents, and cost involved shall be included in the bid prices. Bids to be submitted on the specified bid date, shall conform to the additions and revisions listed herein.

The following questions have been presented by potential Bidders:

 Question: Reference specifications Section 01150, MEASUREMENT AND PAYMENT, page 01150-9, BID ITEM - FORCE MAIN CONNECTIONS, when the second paragraph gets corrected and includes the list of lift stations on the island, we will need to know the disposal site for the septic storage trucks to discharge their load at, please provide this location.

Response: The lift stations on the island that are affected by this project are included in the plans, pumping rates and head conditions. It is the contractor's responsibility to provide an adequate amount of septage storage trucks to prevent sanitary sewer overflows, per their means and methods to make the force main connections.

- Flow from the Imperial House Lift Station or Lift Station 1C may be disposed of in Lift Station 1
 - Lift Station 1 is located at the end of 6th Street South, off of Gulf Drive North
- Flow from Lift Station 3C may be disposed of in Lift Station 5
- If needed, flow from Lift Station 5 may be disposed of in Lift Station 10D
 Dift Station 10D is located at 7800 9th Avenue Northwest

The deadline for clarifications requests has passed and no further questions or requests for clarifications will be accepted.

The Bid Opening time and date shall remain unchanged.

IFB 17-0772GC Addendum 4 Page 2 March 29, 2017

If you have submitted a bid prior to receiving this addendum you may request in writing that your original, sealed bid be returned to your firm. All sealed bids received will be opened on the date stated.

Bids will be received at Manatee County Procurement Division, 1112 Manatee Avenue West, Suite 803, Bradenton, Florida 34205 until March 31, 2017 at 2:00 PM.

Sincerely,

Am Melissa M. Wendel, CPPO Purchasing Official