



1112 Manatee Ave. West  
Bradenton, FL 34205  
[purchasing@mymanatee.org](mailto:purchasing@mymanatee.org)

## Solicitation Addendum

---

Addendum No.: 1  
Solicitation No.: 20-TA003404CD  
Project No.: 6011780  
Solicitation Title: Southwest Water Reclamation Facility Electrical  
Distribution System Rehabilitation  
Addendum Date: August 25, 2020  
Procurement Contact: Sherri Meier

**RFQ No. 20-TA003404CD is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This addendum is hereby incorporated in and made a part of RFQ No. 20-TA003404CD.**

### **CHANGE TO:**

### **SECTION A, INSTRUCTIONS TO PROPOSERS, A.37, SOLICITATION SCHEDULE**

#### **A.37 SOLICITATION SCHEDULE**

The following schedule has been established for this Solicitation process. Refer to the County's website ([www.mymanatee.org](http://www.mymanatee.org) > *Business* > *Bids & Proposals*) for meeting locations and updated information pertaining to any revisions to this schedule.

Scheduled Item	Scheduled Date
Non-Mandatory Solicitation Information Conference and Site Visit Immediately Following at Southwest Water Reclamation Facility, 5105 65 <sup>th</sup> Street West, Bradenton, FL 34210	August 13, 2020 9:30 AM ET
Question and Clarification Deadline	August 21, 2020
Final Addendum Posted	<u>August 28 2020</u>
Proposal Due date and Time	September 9, 2020 by 2:00 PM ET
Technical Evaluation Meeting	September 23, 2020
Technical Evaluation Meeting	September 24, 2020
Interviews (if conducted)	<u>October 7, 2020</u>
<u>Final Technical Evaluation Meeting</u>	<u>October 9, 2020</u>
Projected Award	December 2020

**QUESTIONS AND RESPONSES:**

**Q1. Wondering if temporary power or HVAC units will be necessary for the project? For example, temporary generators.**

R1. Plant must remain fully operational throughout project construction. Contractor will need to plan for temporary power if necessary, to ensure continuous plant operation. This will entail coordination with County Operations staff to minimize impacts to existing treatment facility during construction.

**Q2. Can the sign-in sheet from the site visit be published?**

R2. Yes, as attached to this Addendum 1.

NOTE: Items that are ~~struck through~~ are deleted. Items that are underlined have been added or changed. All other terms and conditions remain as stated in the RFQ.

**END OF ADDENDUM**

**INSTRUCTIONS:**

Receipt of this addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

AUTHORIZED FOR RELEASE



**Procurement Division**  
**Non-Mandatory Info Conference & Site Visit**  
**RFQ No. 20-TA003404CD**  
**Design-Build SWWRF Electrical Distribution System Rehabilitation**  
**August 13, 2020 @ 9:30 AM**  
**5105 65th Street West, Bradenton, FL 34210**

Printed Name	Organization/Agency	Email Address
Steve Antman	Engineered Electric Services	santman@ees cf  .com
Helia Baxley	Wharton-Smith, Inc	hbaxley@whartonsmith.com
MIKE HAGY	WHARTON SMITH, INC.	mhagy@whartonsmith.com
BOB HALLMAN	ENGINEERING DESIGN TECH.	BHALL@EDT1.COM
Suvath Seng	McKim & Creed	sseng@mckimcreed.com
Aubrey Haudricourt	" "	ahaudricourt@mckimcreed.com
Chris Collins	Manatee County	chris.collins@mymanatee.org
Sam Paulline	Manatee County	Sam.Paulline@mymanatee.org
Anthony Benitez	MCPW	anthony.benitez@mymanatee.org
Denise Greer	MCPWUE	denise.greer@mymanatee.org
Charles Paparis	BL Smith	ASMO914@aol.com
CURTIS BARNHILL	BL SMITH	CURTIS@BLSMITHELECTRIC.COM

