



1112 Manatee Avenue West
Bradenton, FL 34205
purchasing@mymanatee.org

Solicitation Addendum

Addendum No.: 2
Solicitation No.: 23-TA004594DJ
Project No.: 6097480 and 6097481
Solicitation Title: Master Lift Station 27A Improvements
Addendum Date: April 7, 2023
Procurement Contact: Dave Janney, Senior Procurement Agent

IFBC 23-TA004594DJ is amended as set forth herein. Responses to questions posed by prospective bidders are provided below. This Addendum is hereby incorporated in and made a part of IFBC 23-TA004594DJ.

The deadline to submit all inquiries concerning interpretation, clarification or additional information pertaining to this IFBC is April 14, 2023.

ADD:

APPENDIX K, ELECTRONIC BID PRICING FORM

The attached Appendix K, Electronic Bid Pricing Form, is hereby incorporated into the IFBC and available for download as a separate attachment.

QUESTIONS AND RESPONSES:

- Q1. Will it be possible to receive a copy of an UNLOCKED version of the Master Lift Station 27A Improvements bid documents please? With the unlocked version of the file, it is easier for us to separate the division specifications and drawings to send to vendors/subcontractors for their scope of work, as well as being able to fill out the required Bid Forms to be submitted.?**
- R1. Due to the documents being signed and sealed we are not able to provide an unlocked version.

Q2. Do you have an Excel Bid Sheet for this project mentioned above?

R2. Appendix K, Electronic Bid Pricing Form, available for download as a separate attachment.

Q3. Please provide a bypass specification with the maximum and average GPM and TDH for this lift station as well as the anticipated suction and discharge points.

R3. Flow can vary between 2,900 and 7,600gpm depending on what the other lift stations deliver into the common forcemain. The TDH can vary from approximately 50ft – 90ft

Q4. Is KSB an acceptable supplier for submersible pumps?

R4. Yes, KSB pumps are a County acceptable supplier of pumps for this project.

NOTE:

Deleted items will be ~~struck through~~, added or modified items will be underlined. All other terms and conditions remain as stated in the IFBC.

INSTRUCTIONS:

Receipt of this Addendum must be acknowledged as instructed in the solicitation document. Failure to acknowledge receipt of this Addendum may result in the response being deemed non-responsive.

END OF ADDENDUM

AUTHORIZED FOR RELEASE